


# PROBLEM SUMMARY

Sample Rating Trend


ADDITIVES

Area  
**MELT SHOP - BAGHOUSE FANS**  
Machine Id  
**M/S BAGHOUSE FAN 151B M/S (S/N 15-6400-2000-1010)**  
Component  
**Inboard Journal Bearing**  
Fluid  
**MOBIL SHC 627 (3 LTR)**



## COMPONENT CONDITION SUMMARY

### ▲ Additives



## RECOMMENDATION

We suspect abnormal contamination may be due to sampling method. No corrective action is recommended at this time. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	NORMAL	NORMAL
Molybdenum	ppm	ASTM D5185m		▲ 276	0	0
Zinc	ppm	ASTM D5185m		▲ 35	3	4
Debris	scalar	*Visual	NONE	▲ MODER	NONE	LIGHT

Customer Id: OUTCALAL  
Sample No.: RP0035058  
Lab Number: 05865699  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 04 Apr 2023 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The water content is negligible. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 06 Dec 2022 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The water content is negligible. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 16 Aug 2022 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The water content is negligible. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



## ADDITIVES



Area  
**MELT SHOP - BAGHOUSE FANS**  
 Machine Id  
**M/S BAGHOUSE FAN 151B M/S (S/N 15-6400-2000-1010)**  
 Component  
**Inboard Journal Bearing**  
 Fluid  
**MOBIL SHC 627 (3 LTR)**

### DIAGNOSIS

#### Recommendation

We suspect abnormal contamination may be due to sampling method. No corrective action is recommended at this time. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

Moderate concentration of visible dirt/debris present in the oil. The water content is negligible.

#### Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>RP0035058</b>	RP0029657	RP0030827
Sample Date	Client Info		<b>05 Jun 2023</b>	04 Apr 2023	06 Dec 2022
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	NORMAL	NORMAL

### WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		<b>14</b>	10	9
Iron	ppm	ASTM D5185m >60	<b>11</b>	13	11
Chromium	ppm	ASTM D5185m >20	<b>&lt;1</b>	0	<1
Nickel	ppm	ASTM D5185m >20	<b>0</b>	0	1
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >4	<b>&lt;1</b>	0	0
Lead	ppm	ASTM D5185m >250	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >125	<b>0</b>	0	0
Tin	ppm	ASTM D5185m >80	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>6</b>	0	0
Barium	ppm	ASTM D5185m	<b>3</b>	<1	1
Molybdenum	ppm	ASTM D5185m	<b>▲ 276</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	1	<1
Magnesium	ppm	ASTM D5185m	<b>5</b>	4	1
Calcium	ppm	ASTM D5185m	<b>9</b>	5	3
Phosphorus	ppm	ASTM D5185m	<b>593</b>	488	421
Zinc	ppm	ASTM D5185m	<b>▲ 35</b>	3	4

### CONTAMINANTS


	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>3</b>	0	<1
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Potassium	ppm	ASTM D5185m >20	<b>0</b>	<1	<1
Water	%	ASTM D6304 >2	<b>0.011</b>	0.010	0.004
ppm Water	ppm	ASTM D6304	<b>114.1</b>	101.0	45.0

### FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>1.02</b>	0.36	0.42


# OIL ANALYSIS REPORT

## ▲ Additives




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	▲ MODER	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

## Water




FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	99.1	96.2	102

## SAMPLE IMAGES




## Water




## GRAPHS


### Ferrous Alloys




### Non-ferrous Metals




### Viscosity @ 40°C




### PQ




### Acid Number



## Viscosity @ 40°C



## PQ



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : RP0035058 **Received** : 06 Jun 2023  
**Lab Number** : 05865699 **Diagnosed** : 08 Jun 2023  
**Unique Number** : 10500164 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: PQ )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**OUTOKUMPU STAINLESS USA**  
 HWY 43 N  
 CALVERT, AL  
 US 36513  
 Contact: MARIO JOHNSON  
 Mario.johnson@outokumpu.com  
 T: (251)321-4105  
 F: x: