


PROBLEM SUMMARY

Sample Rating Trend



VIS DEBRIS



Machine Id
BOSS XTO-LEGG FED 1 TOWER (S/N 116099)
 Component
Compressor
 Fluid
TULCO LUBSOIL LPG WS 150 (7 GAL)

COMPONENT CONDITION SUMMARY

No relevant graphs to display

RECOMMENDATION

We recommend you service the filters on this component. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS

Sample Status		ABNORMAL	NORMAL	ATTENTION
Debris	scalar *Visual	▲ HEAVY	NONE	NONE

Customer Id: RICHOB
Sample No.: TO90003413
Lab Number: 05867321
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	Nov 30 2023	?	We recommend you service the filters on this component.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

03 Apr 2023 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



14 Nov 2022 Diag: Angela Borella

ISO



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



09 Sep 2022 Diag: Doug Bogart

ISO




No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 6 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Machine Id
BOSS XTO-LEGG FED 1 TOWER (S/N 116099)
 Component
Compressor
 Fluid
TULCO LUBSOIL LPG WS 150 (7 GAL)



DIAGNOSIS

- Recommendation**
We recommend you service the filters on this component. We were unable to perform a particle count due to a high concentration of particles present in this sample.
- Wear**
All component wear rates are normal.
- Contamination**
Moderate concentration of visible dirt/debris present in the oil.
- Fluid Condition**
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	TO90003413	TO90002793	TO90002628
Sample Date	Client Info	17 May 2023	03 Apr 2023	14 Nov 2022
Machine Age	hrs	27733	26727	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	NORMAL	ATTENTION

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >50	2	4	2
Chromium	ppm	ASTM D5185m >10	0	0	0
Nickel	ppm	ASTM D5185m	<1	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	0	0	0
Lead	ppm	ASTM D5185m >25	0	0	<1
Copper	ppm	ASTM D5185m >50	<1	<1	<1
Tin	ppm	ASTM D5185m >15	<1	<1	<1
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 0	0	0	0
Barium	ppm	ASTM D5185m 0	0	0	0
Molybdenum	ppm	ASTM D5185m 0	0	0	0
Manganese	ppm	ASTM D5185m	<1	0	0
Magnesium	ppm	ASTM D5185m 0	1	0	<1
Calcium	ppm	ASTM D5185m 0	0	2	0
Phosphorus	ppm	ASTM D5185m 0	20	275	361
Zinc	ppm	ASTM D5185m 0	0	<1	0
Sulfur	ppm	ASTM D5185m 0	384	58	0

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >25	1	0	<1
Sodium	ppm	ASTM D5185m	<1	11	5
Potassium	ppm	ASTM D5185m >20	2	1	2
Water	%	ASTM D6304 >2.26	0.752	0.618	0.427
ppm Water	ppm	ASTM D6304 >22600	7520	6180	4270





FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	---	2142	▲ 10954
Particles >6µm	ASTM D7647 >1300	---	545	▲ 1627
Particles >14µm	ASTM D7647 >320	---	44	32
Particles >21µm	ASTM D7647 >80	---	17	5
Particles >38µm	ASTM D7647 >20	---	0	1
Particles >71µm	ASTM D7647 >4	---	0	1
Oil Cleanliness	ISO 4406 (c) >20/17/15	---	18/16/13	▲ 21/18/12

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.23	0.306	0.31


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	▲ HEAVY	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2.26	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	151	104	115	127
Visc @ 100°C	cSt	ASTM D445	28	19.6	21.3	22.2
Viscosity Index (VI)	Scale	ASTM D2270	224	212	212	204

SAMPLE IMAGES



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO90003413 **Received** : 07 Jun 2023
Lab Number : 05867321 **Diagnosed** : 10 Jun 2023
Unique Number : 10507105 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

RICHARDS ENERGY COMPRESSION
 1629 WEST BENDER
 HOBBS, NM
 US 88240
 Contact: BILL RICHARDSON
 richardsenergy@windstream.net

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)