



Machine Id
BOSS ROSS DRAW 3031-TOWER-XTO (S/N 120970)
 Component
Compressor
 Fluid
TULCO LUBSOIL LPG WS 150 (10 GAL)



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>10000	▲ 71504	▲ 146228	---
Particles >6µm	ASTM D7647	>1300	▲ 42790	▲ 58610	---
Particles >14µm	ASTM D7647	>320	▲ 7382	▲ 3411	---
Particles >21µm	ASTM D7647	>80	▲ 1272	▲ 480	---
Oil Cleanliness	ISO 4406 (c)	>20/17/15	▲ 23/23/20	▲ 24/23/19	---

Customer Id: RICHOB
Sample No.: TO90003376
Lab Number: 05867340
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	Dec 01 2023	?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

11 Apr 2023 Diag: Don Baldrige

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



23 Feb 2023 Diag: Don Baldrige

VIS DEBRIS



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. High concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



06 Dec 2022 Diag: Don Baldrige

VIS DEBRIS




No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



Machine Id
BOSS ROSS DRAW 3031-TOWER-XTO (S/N 120970)
 Component
Compressor
 Fluid
TULCO LUBSOIL LPG WS 150 (10 GAL)



DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION	method	limit/base	current	history1	history2
Sample Number	Client Info		TO90003376	TO90002803	TO90002913
Sample Date	Client Info		24 May 2023	11 Apr 2023	23 Feb 2023
Machine Age	hrs	Client Info	18898	17892	16815
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<1	3	2
Chromium	ppm	ASTM D5185m >10	0	0	0
Nickel	ppm	ASTM D5185m	<1	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	0	0	0
Lead	ppm	ASTM D5185m >25	<1	0	0
Copper	ppm	ASTM D5185m >50	2	5	6
Tin	ppm	ASTM D5185m >15	1	<1	<1
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	0	0	0
Barium	ppm	ASTM D5185m 0	0	0	0
Molybdenum	ppm	ASTM D5185m 0	0	0	0
Manganese	ppm	ASTM D5185m	<1	0	0
Magnesium	ppm	ASTM D5185m 0	2	0	0
Calcium	ppm	ASTM D5185m 0	0	1	2
Phosphorus	ppm	ASTM D5185m 0	279	279	284
Zinc	ppm	ASTM D5185m 0	0	2	1
Sulfur	ppm	ASTM D5185m 0	550	390	321


CONTAMINANTS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<1	0	0
Sodium	ppm	ASTM D5185m	14	22	23
Potassium	ppm	ASTM D5185m >20	2	1	1
Water	%	ASTM D6304 >2.26	0.845	0.712	0.414
ppm Water	ppm	ASTM D6304 >22600	8450	7120	4140

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	▲ 71504	▲ 146228	---
Particles >6µm	ASTM D7647	>1300	▲ 42790	▲ 58610	---
Particles >14µm	ASTM D7647	>320	▲ 7382	▲ 3411	---
Particles >21µm	ASTM D7647	>80	▲ 1272	▲ 480	---
Particles >38µm	ASTM D7647	>20	19	▲ 21	---
Particles >71µm	ASTM D7647	>4	0	1	---
Oil Cleanliness	ISO 4406 (c)	>20/17/15	▲ 23/23/20	▲ 24/23/19	---

FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.15	0.22	0.132


OIL ANALYSIS REPORT

▲ Particle Trend




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	▲ HEAVY
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2.26	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

Water (KF)




FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	151	124	137
Visc @ 100°C	cSt	ASTM D445	28	23.0	25.1
Viscosity Index (VI)	Scale	ASTM D2270	224	210	218


Viscosity @ 100°C




SAMPLE IMAGES




Water (KF)



GRAPHS



Viscosity @ 100°C



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO90003376 **Received** : 07 Jun 2023
Lab Number : 05867340 **Diagnosed** : 10 Jun 2023
Unique Number : 10507124 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

RICHARDS ENERGY COMPRESSION
 1629 WEST BENDER
 HOBBS, NM
 US 88240
 Contact: BILL RICHARDSON
 richardsenergy@windstream.net

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: