

PROBLEM SUMMARY


Sample Rating Trend

VIS DEBRIS

BOSS HARROW WEST (S/N 129147)

Compressor

TULCO LUBSOIL LPG WS 150 (1 GAL)





COMPONENT CONDITION SUMMARY

No relevant graphs to display

RECOMMENDATION

We recommend you service the filters on this component. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC T	TEST RESULTS					
Sample Status			ABNORMAL	NORMAL	NORMAL	
Dehris	scalar *Visual	NONE	△ MODER	LIGHT	NONE	

Customer Id: RICHOB Sample No.: TO90003368 Lab Number: 05867346 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	Dec 01 2023	?	We recommend you service the filters on this component.
Alert			?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

21 Apr 2023 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



15 Mar 2023 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

15 Dec 2022 Diag: Don Baldridge

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.





OIL ANALYSIS REPORT

Sample Rating Trend

VIS DEBRIS



Machine Id

BOSS HARROW WEST (S/N 129147)

Component

Compressor

TULCO LUBSOIL LPG WS 150 (1 GAL)

Fluid

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jul2022	Nov2022 Dec2023	2 Mar2023 Apr2023	May2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		TO90003368	TO90002808	TO90002833
Sample Date		Client Info		09 May 2023	21 Apr 2023	15 Mar 2023
Machine Age	hrs	Client Info		8396	8177	7581
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2	1	1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m		<1	<1	<1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	0	0
Lead	ppm	ASTM D5185m	>25	0	0	0
Copper	ppm	ASTM D5185m	>50	<1	<1	<1
Tin	ppm	ASTM D5185m	>15	1	0	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	0	1	0	0
Calcium	ppm	ASTM D5185m	0	0	2	2
Phosphorus	ppm	ASTM D5185m	0	128	34	37
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	0	47	378	349
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	0
Sodium	ppm	ASTM D5185m		0	12	11
Potassium	ppm	ASTM D5185m	>20	2	<1	<1
Water	%	ASTM D6304	>2.26	0.880	0.540	0.780
ppm Water	ppm	ASTM D6304	>22600	8800	5400	7800
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>10000		3862	3488
Particles >6µm		ASTM D7647	>1300		1206	780

ASTM D7647 >320

ASTM D7647 >80

ASTM D7647 >20

ASTM D7647 >4

>20/17/15

limit/base

ISO 4406 (c)

method

mg KOH/g ASTM D8045

Particles >14µm

Particles >21µm

Particles >38µm

Particles >71µm

Oil Cleanliness

Acid Number (AN)

FLUID DEGRADATION

0.41

99

22

2

0

current

0.39

19/17/14

history1

65

17

0

19/17/13

0.426

history2



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number

Unique Number : 10507130

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 07 Jun 2023 : TO90003368 : 05867346 Diagnosed : 10 Jun 2023 Diagnostician : Doug Bogart

Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

RICHARDS ENERGY COMPRESSION

1629 WEST BENDER HOBBS, NM US 88240

Contact: BILL RICHARDSON

richardsenergy@windstream.net T:

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: