



Machine Id
BOSS PLU PIERCE CANYON 20-24-30 VRT (S/N 117522)
 Component
Compressor
 Fluid
TULCO LUBSOIL LPG WS 150 (10 GAL)



COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status			ABNORMAL	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>10000	▲ 39829	▲ 113208	▲ 13664
Particles >6µm	ASTM D7647	>1300	▲ 14202	▲ 40161	▲ 2692
Particles >14µm	ASTM D7647	>320	▲ 1752	▲ 2498	134
Particles >21µm	ASTM D7647	>80	▲ 514	▲ 517	36
Oil Cleanliness	ISO 4406 (c)	>20/17/15	▲ 22/21/18	▲ 24/23/18	▲ 21/19/14

Customer Id: RICHOB
 Sample No.: TO90003420
 Lab Number: 05867358
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	MISSED	Nov 30 2023	?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

28 Apr 2023 Diag: Doug Bogart

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



22 Mar 2023 Diag: Don Baldrige

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



16 Dec 2022 Diag: Don Baldrige

ISO




No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id
BOSS PLU PIERCE CANYON 20-24-30 VRT (S/N 117522)
 Component
Compressor
 Fluid
TULCO LUBSOIL LPG WS 150 (10 GAL)

DIAGNOSIS

- Recommendation**
We recommend you service the filters on this component. Resample at the next service interval to monitor.
- Wear**
All component wear rates are normal.
- Contamination**
There is a high amount of particulates present in the oil.
- Fluid Condition**
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION	method	limit/base	current	history1	history2
Sample Number	Client Info		TO90003420	TO90003397	TO90002852
Sample Date	Client Info		16 May 2023	28 Apr 2023	22 Mar 2023
Machine Age	hrs	Client Info	17320	16930	16668
Oil Age	hrs	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	12	8	9
Chromium	ppm	ASTM D5185m >10	0	0	0
Nickel	ppm	ASTM D5185m	<1	<1	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	<1	0
Aluminum	ppm	ASTM D5185m >25	0	0	0
Lead	ppm	ASTM D5185m >25	0	0	0
Copper	ppm	ASTM D5185m >50	<1	<1	<1
Tin	ppm	ASTM D5185m >15	1	<1	<1
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	0	0	0
Barium	ppm	ASTM D5185m 0	0	0	0
Molybdenum	ppm	ASTM D5185m 0	0	0	0
Manganese	ppm	ASTM D5185m	<1	<1	0
Magnesium	ppm	ASTM D5185m 0	3	2	0
Calcium	ppm	ASTM D5185m 0	4	2	5
Phosphorus	ppm	ASTM D5185m 0	9	10	6
Zinc	ppm	ASTM D5185m 0	17	14	11
Sulfur	ppm	ASTM D5185m 0	263	230	128


CONTAMINANTS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	1	1	<1
Sodium	ppm	ASTM D5185m	7	9	6
Potassium	ppm	ASTM D5185m >20	4	4	2
Water	%	ASTM D6304 >2.26	1.05	1.14	0.721
ppm Water	ppm	ASTM D6304 >22600	10500	11400	7210

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	▲ 39829	▲ 113208	▲ 13664
Particles >6µm	ASTM D7647	>1300	▲ 14202	▲ 40161	▲ 2692
Particles >14µm	ASTM D7647	>320	▲ 1752	▲ 2498	134
Particles >21µm	ASTM D7647	>80	▲ 514	▲ 517	36
Particles >38µm	ASTM D7647	>20	16	10	1
Particles >71µm	ASTM D7647	>4	0	0	0
Oil Cleanliness	ISO 4406 (c)	>20/17/15	▲ 22/21/18	▲ 24/23/18	▲ 21/19/14


FLUID DEGRADATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.35	0.23	0.12

OIL ANALYSIS REPORT


Particle Trend




Water (KF)




Viscosity @ 100°C



Water (KF)



Viscosity @ 100°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>2.26	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	151	126	118
Visc @ 100°C	cSt	ASTM D445	28	23.2	22.1
Viscosity Index (VI)	Scale	ASTM D2270	224	215	216

SAMPLE IMAGES


Color

Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO90003420 **Received** : 07 Jun 2023
Lab Number : 05867358 **Diagnosed** : 11 Jun 2023
Unique Number : 10507142 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

RICHARDS ENERGY COMPRESSION
 1629 WEST BENDER
 HOBBS, NM
 US 88240
 Contact: BILL RICHARDSON
 richardsenergy@windstream.net

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: