



# PROBLEM SUMMARY

Area  
**Paper Cup Machines**  
 Machine Id  
**PMC 1001 POS-125 (S/N 50299)**  
 Component  
**Circulating System**  
 Fluid  
**SUMMIT Syngear SH-1032 320 (85 GAL)**

Sample Rating Trend



## COMPONENT CONDITION SUMMARY



### RECOMMENDATION

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. ( Customer Sample Comment: Quarterly oil sample )

### PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	ABNORMAL
Water	%	ASTM D6304		▲ <b>0.126</b>	0.015	---
ppm Water	ppm	ASTM D6304		▲ <b>1260</b>	156.2	---
Silt	scalar	*Visual	NONE	▲ <b>MODER</b>	▲ MODER	▲ MODER
Appearance	scalar	*Visual	NORML	▲ <b>HAZY</b>	▲ HAZY	▲ SOLID
Emulsified Water	scalar	*Visual		▲ <b>0.2%</b>	NEG	NEG
Free Water	scalar	*Visual		● <b>10.0</b>	NEG	>10%

Customer Id: DARDALTX  
 Sample No.: TO50001767  
 Lab Number: 05867875  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Don Baldrige +1  
[don.b505@comcast.net](mailto:don.b505@comcast.net)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off	MISSED	Sep 05 2023	?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	MISSED	Sep 05 2023	?	We recommend an early resample to monitor this condition.
Check Water Access	MISSED	Sep 05 2023	?	We advise that you check for the source of water entry.

## HISTORICAL DIAGNOSIS

### 30 Mar 2023 Diag: Angela Borella

#### SEDIMENT



Resample at the next service interval to monitor. All component wear rates are normal. Appearance is hazy. There is a moderate amount of visible silt present in the sample. The AN level is acceptable for this fluid.

view report



### 27 Feb 2023 Diag: Jonathan Hester

#### WEAR



We advise that you follow the water drain-off procedure for this component to remove more dense oil layer. We advise an early resample to confirm this situation. All component wear rates are normal. Appearance is layered. There is a moderate amount of visible silt present in the sample. The AN level is acceptable for this fluid.

view report



### 09 Dec 2022 Diag: Don Baldrige

#### CONTAMINANT




Resample at the next service interval to monitor. All component wear rates are normal. Appearance is hazy. There is no indication of any contamination in the oil. The condition of the oil is acceptable for the time in service.

view report



Area  
**Paper Cup Machines**  
 Machine Id  
**PMC 1001 POS-125 (S/N 50299)**  
 Component  
**Circulating System**  
 Fluid  
**SUMMIT Syngear SH-1032 320 (85 GAL)**



## DIAGNOSIS

### Recommendation

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. ( Customer Sample Comment: Quarterly oil sample )

### Wear

All component wear rates are normal.

### Contamination

Appearance is hazy. There is a moderate amount of visible silt present in the sample. There is a light concentration of water present in the oil. Excessive free water present.

### Fluid Condition

The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>TO50001767</b>	TO50001555	TO50001407
Sample Date	Client Info		<b>05 Jun 2023</b>	30 Mar 2023	27 Feb 2023
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>SEVERE</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		<b>26</b>	16	22
Iron	ppm	ASTM D5185m	<b>18</b>	16	19
Chromium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Nickel	ppm	ASTM D5185m	<b>18</b>	0	▲ 24
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Silver	ppm	ASTM D5185m	<b>0</b>	<1	2
Aluminum	ppm	ASTM D5185m	<b>&lt;1</b>	2	2
Lead	ppm	ASTM D5185m	<b>0</b>	<1	<1
Copper	ppm	ASTM D5185m	<b>2</b>	2	2
Tin	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>128</b>	112	109
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	1
Magnesium	ppm	ASTM D5185m	<b>&lt;1</b>	10	6
Calcium	ppm	ASTM D5185m	<b>0</b>	4	4
Phosphorus	ppm	ASTM D5185m	<b>484</b>	533	418
Zinc	ppm	ASTM D5185m	<b>0</b>	5	5
Sulfur	ppm	ASTM D5185m	<b>9830</b>	10044	8902






## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<b>9829</b>	3783	10000
Sodium	ppm	ASTM D5185m	<b>2</b>	1	2
Potassium	ppm	ASTM D5185m >20	<b>0</b>	<1	0
Water	%	ASTM D6304	▲ <b>0.126</b>	0.015	---
ppm Water	ppm	ASTM D6304	▲ <b>1260</b>	156.2	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.94</b>	0.92	---


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	▲ MODER
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ HAZY	▲ HAZY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	▲ 0.2%	NEG	NEG
Free Water	scalar	*Visual	◆ 10.0	NEG	>10%

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	326	355	346
Visc @ 100°C	cSt	ASTM D445	33.4	35.4	34.0
Viscosity Index (VI)	Scale	ASTM D2270	145	143	140

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : TO50001767 **Received** : 08 Jun 2023  
**Lab Number** : 05867875 **Diagnosed** : 15 Jun 2023  
**Unique Number** : 10507659 **Diagnostician** : Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, KV100, PQ, PrtCount, VI )  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**DART CONTAINER CORPORATION**  
 4444 W LEADBETTER DR  
 DALLAS, TX  
 US 75236  
 Contact: YON PALOMINO  
 yon.palomino@dart.biz  
 T: (214)775-5673  
 F: