


PROBLEM SUMMARY

Area
Paper Cup Machines
 Machine Id
PMC 1001 POS-121 (S/N 50286)
 Component
Circulating System
 Fluid
SUMMIT Syngear SH-1032 320 (85 GAL)

Sample Rating Trend



WATER



COMPONENT CONDITION SUMMARY

No relevant graphs to display

RECOMMENDATION

We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor. (Customer Sample Comment: Quarterly oil sample cs)

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Silt	scalar	*Visual	NONE	▲ MODER	▲ HEAVY	NONE
Appearance	scalar	*Visual	NORML	▲ HAZY	▲ HAZY	▲ HAZY
Free Water	scalar	*Visual		▲ 1.0	NEG	NEG

Customer Id: DARDALTX
Sample No.: TO50001768
Lab Number: 05867876
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component.

HISTORICAL DIAGNOSIS

22 May 2023 Diag: Jonathan Hester

WATER



We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Appearance is hazy. There is a light concentration of water present in the oil. There is a high amount of visible silt present in the sample. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



30 Mar 2023 Diag: Angela Borella

CONTAMINANT



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. Appearance is hazy. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

view report



02 Mar 2023 Diag: Jonathan Hester

WATER




We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor. All component wear rates are normal. Appearance is hazy. Free water present. The condition of the oil is acceptable for the time in service.

view report



Area
Paper Cup Machines
 Machine Id
PMC 1001 POS-121 (S/N 50286)
 Component
Circulating System
 Fluid
SUMMIT Syngear SH-1032 320 (85 GAL)



DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor. (Customer Sample Comment: Quarterly oil sample cs)

Wear

All component wear rates are normal.

Contamination

Appearance is hazy. Moderate concentration of visible dirt/debris present in the oil. Free water present.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history 1	history 2
Sample Number	Client Info	TO50001768	TO50001757	TO50001554
Sample Date	Client Info	05 Jun 2023	22 May 2023	30 Mar 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history 1	history 2	
PQ	ASTM D8184	12	12	16	
Iron	ppm	ASTM D5185m	12	12	7
Chromium	ppm	ASTM D5185m	<1	0	0
Nickel	ppm	ASTM D5185m	6	0	0
Titanium	ppm	ASTM D5185m	<1	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m	<1	3	2
Lead	ppm	ASTM D5185m	0	0	0
Copper	ppm	ASTM D5185m	2	<1	1
Tin	ppm	ASTM D5185m	<1	<1	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history 1	history 2	
Boron	ppm	ASTM D5185m	97	89	80
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	<1	0	10
Calcium	ppm	ASTM D5185m	1	6	5
Phosphorus	ppm	ASTM D5185m	468	496	497
Zinc	ppm	ASTM D5185m	0	0	4
Sulfur	ppm	ASTM D5185m	8059	7765	7878

CONTAMINANTS

method	limit/base	current	history 1	history 2		
Silicon	ppm	ASTM D5185m	3523	3304	603	
Sodium	ppm	ASTM D5185m	3	3	2	
Potassium	ppm	ASTM D5185m	>20	0	<1	0
Water	%	ASTM D6304	0.090	▲ 0.159	0.008	
ppm Water	ppm	ASTM D6304	900	▲ 1590	83.8	






FLUID CLEANLINESS

method	limit/base	current	history 1	history 2	
Particles >4µm	ASTM D7647	>1300	---	---	▲ 7487
Particles >6µm	ASTM D7647	>320	---	---	▲ 1053
Particles >14µm	ASTM D7647	>80	---	---	60
Particles >21µm	ASTM D7647	>20	---	---	12
Particles >38µm	ASTM D7647	>4	---	---	1
Particles >71µm	ASTM D7647	>3	---	---	0
Oil Cleanliness	ISO 4406 (c)	>17/15/13	---	---	▲ 20/17/13

FLUID DEGRADATION

method	limit/base	current	history 1	history 2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.72	0.66	0.69


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	▲ HEAVY
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ HAZY	▲ HAZY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	0.2%	▲ 0.2%	NEG
Free Water	scalar	*Visual	1.0	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	326	407	417
Visc @ 100°C	cSt	ASTM D445	33.4	38.8	39.0
Viscosity Index (VI)	Scale	ASTM D2270	145	142	140

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
---------------	--------	------------	---------	-----------	-----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO50001768 **Received** : 08 Jun 2023
Lab Number : 05867876 **Diagnosed** : 15 Jun 2023
Unique Number : 10507660 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: KF, KV100, PQ, PrtCount, VI)
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

DART CONTAINER CORPORATION
 4444 W LEADBETTER DR
 DALLAS, TX
 US 75236
 Contact: YON PALOMINO
 yon.palomino@dart.biz
 T: (214)775-5673
 F: