


PROBLEM SUMMARY

Sample Rating Trend



SEDIMENT



Machine Id
ALPHA BLUE HEATER (S/N 97093)
 Component
Heat Transfer Fluid
 Fluid
TULCO LUBSOIL HEAT TRANSFER 250 (--- GAL)

COMPONENT CONDITION SUMMARY

No relevant graphs to display

RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	SEVERE
Silt	scalar	*Visual	NONE	▲ MODER	NONE	NONE

Customer Id: BLUMUSOK
Sample No.: TO10001845
Lab Number: 05870920
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

10 Aug 2022 Diag: Doug Bogart

WATER



Recommend drain oil if not already done and flush with cleaner before refilling with oil. Please note that the oil was too thick to perform accurate viscosity tests. The iron level is abnormal. There is a moderate concentration of water present in the oil. The AN level is above the recommended limit. The oil is oxidized and beyond the limit of serviceability.

[view report](#)



23 Nov 2021 Diag: Doug Bogart

WEAR



Recommend drain oil if not already done and flush with cleaner before refilling with oil. Please note that the oil was too thick to perform some of the normal laboratory tests. The iron level is abnormal. No contaminants were detected in the oil. The AN level is above the recommended limit. The oil is highly oxidized and beyond the limit of serviceability.

[view report](#)



06 Feb 2020 Diag: Doug Bogart

WEAR




Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please note that this is a corrected copy for data entry updates. The iron level is abnormal. There is no indication of any contamination in the oil. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

[view report](#)



OIL ANALYSIS REPORT

Sample Rating Trend



SEDIMENT



Machine Id
ALPHA BLUE HEATER (S/N 97093)

Component
Heat Transfer Fluid

Fluid
TULCO LUBSOIL HEAT TRANSFER 250 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of visible silt present in the sample.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history 1	history 2
Sample Number	Client Info		TO10001845	TO10001173	TO10000612
Sample Date	Client Info		07 Jun 2023	10 Aug 2022	23 Nov 2021
Machine Age	Client Info		14	0	0
Oil Age	Client Info		0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	SEVERE

WEAR METALS

	method	limit/base	current	history 1	history 2
Iron	ppm ASTM D5185m		155	▲ 598	● 742
Chromium	ppm ASTM D5185m		0	0	<1
Nickel	ppm ASTM D5185m		0	0	0
Titanium	ppm ASTM D5185m		0	0	<1
Silver	ppm ASTM D5185m		0	0	0
Aluminum	ppm ASTM D5185m		0	1	<1
Lead	ppm ASTM D5185m		0	0	0
Copper	ppm ASTM D5185m		0	<1	<1
Tin	ppm ASTM D5185m		<1	0	0
Antimony	ppm ASTM D5185m		---	---	0
Vanadium	ppm ASTM D5185m		0	0	0
Cadmium	ppm ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history 1	history 2
Boron	ppm ASTM D5185m		0	<1	31
Barium	ppm ASTM D5185m		0	2	0
Molybdenum	ppm ASTM D5185m		0	<1	<1
Manganese	ppm ASTM D5185m		2	6	8
Magnesium	ppm ASTM D5185m		0	1	1
Calcium	ppm ASTM D5185m		13	9	16
Phosphorus	ppm ASTM D5185m		10	23	13
Zinc	ppm ASTM D5185m		0	5	10
Sulfur	ppm ASTM D5185m	1400	1305	1011	913
Lithium	ppm ASTM D5185m		---	---	0





CONTAMINANTS

	method	limit/base	current	history 1	history 2
Silicon	ppm ASTM D5185m		27	2	<1
Sodium	ppm ASTM D5185m		2	3	7
Potassium	ppm ASTM D5185m	>20	<1	1	0
Water	% ASTM D6304		0.007	▲ 0.751	---
ppm Water	ppm ASTM D6304		71.5	▲ 7510	---

FLUID DEGRADATION

	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g ASTM D8045	0.05	0.39	▲ 1.70	● 5.431


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	NONE
Debris	scalar	*Visual	NONE	NONE	▲ SOLID
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	▲ 0.2%	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	52	▲ 54.6	2652
Visc @ 100°C	cSt	ASTM D445	7.5	▲ 7.9	26.6
Viscosity Index (VI)	Scale	ASTM D2270	106	111	---

SAMPLE IMAGES



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO10001845 **Received** : 12 Jun 2023
Lab Number : 05870920 **Diagnosed** : 14 Jun 2023
Unique Number : 10510704 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, KV100, PrtCount, VI)

ERGON - CALLERY - ALPHA - BETA - DELTA
 2501 PORT PL
 MUSKOGEE, OK
 US 74403
 Contact: COLE HOWELL
 Donovan.Howell@ergon.com
 T:
 F: (918)683-6061

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)