


PROBLEM SUMMARY


Sample Rating Trend



Area
Paper Cup Machines
Machine Id
PMC 1003 POS-214 (S/N 15960)
Component
Circulating System
Fluid
SUMMIT Syngear SH-1032 320 (85 GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. (Customer Sample Comment: Cs)

PROBLEMATIC TEST RESULTS

Sample Status	ASTM D7647	ISO	ABNORMAL	ABNORMAL	ABNORMAL
Particles >4µm	>1300	▲ 174764	---	---	---
Particles >6µm	>320	▲ 76414	---	---	---
Particles >14µm	>80	▲ 3263	---	---	---
Particles >21µm	>20	▲ 485	---	---	---
Particles >38µm	>4	▲ 17	---	---	---
Oil Cleanliness	ISO 4406 (c) >17/15/13	▲ 25/23/19	---	---	---

Customer Id: DARDALTX
Sample No.: TO50001689
Lab Number: 05873184
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We recommend you service the filters on this component if applicable.

HISTORICAL DIAGNOSIS

27 Feb 2023 Diag: Jonathan Hester

VIS DEBRIS



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The condition of the oil is acceptable for the time in service.

[view report](#)



28 Nov 2022 Diag: Doug Bogart

SEDIMENT



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of visible silt present in the sample. Moderate concentration of visible dirt/debris present in the oil. Elemental level of silicon (Si) above normal. The condition of the oil is acceptable for the time in service.

[view report](#)



25 Oct 2022 Diag: Don Baldrige

DIRT




No corrective action is recommended at this time. Resample at the next service interval to monitor. Moderate concentration of visible metal present. All component wear rates are normal. There is no indication of any contamination in the oil. Silicon noted. The condition of the oil is acceptable for the time in service.

[view report](#)



Area
Paper Cup Machines
 Machine Id
PMC 1003 POS-214 (S/N 15960)
 Component
Circulating System
 Fluid
SUMMIT Syngear SH-1032 320 (85 GAL)



DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. (Customer Sample Comment: Cs)

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	TO50001689	TO50001413	TO50001205
Sample Date	Client Info	09 Jun 2023	27 Feb 2023	28 Nov 2022
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184	30	28	4
Iron	ppm	22	19	18
Chromium	ppm	0	0	0
Nickel	ppm	5	5	0
Titanium	ppm	0	<1	0
Silver	ppm	0	0	0
Aluminum	ppm	0	<1	<1
Lead	ppm	<1	0	<1
Copper	ppm	2	2	2
Tin	ppm	<1	0	<1
Vanadium	ppm	0	0	0
Cadmium	ppm	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	18	17	22
Barium	ppm	0	0	0
Molybdenum	ppm	0	0	0
Manganese	ppm	<1	1	<1
Magnesium	ppm	<1	5	0
Calcium	ppm	2	1	<1
Phosphorus	ppm	417	433	443
Zinc	ppm	3	5	2
Sulfur	ppm	5619	5842	6095

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	2341	2569	2861
Sodium	ppm	0	<1	1
Potassium	ppm	1	1	0
Water	%	0.013	---	---
ppm Water	ppm	136.3	---	---






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	▲ 174764	---	---
Particles >6µm	ASTM D7647	▲ 76414	---	---
Particles >14µm	ASTM D7647	▲ 3263	---	---
Particles >21µm	ASTM D7647	▲ 485	---	---
Particles >38µm	ASTM D7647	▲ 17	---	---
Particles >71µm	ASTM D7647	0	---	---
Oil Cleanliness	ISO 4406 (c)	▲ 25/23/19	---	---

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	0.71	---	---

OIL ANALYSIS REPORT




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	MODER	▲ MODER
Debris	scalar	*Visual	NONE	MODER	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	HAZY	▲ HAZY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	326	298	296
Visc @ 100°C	cSt	ASTM D445	33.4	29.8	28.9
Viscosity Index (VI)	Scale	ASTM D2270	145	136	131






SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color

Bottom



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO50001689 **Received** : 14 Jun 2023
Lab Number : **05873184** **Diagnosed** : 15 Jun 2023
Unique Number : 10512968 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KF, KV100, PQ, PrtCount, VI)

DART CONTAINER CORPORATION
 4444 W LEADBETTER DR
 DALLAS, TX
 US 75236
 Contact: YON PALOMINO
 yon.palomino@dart.biz
 T: (214)775-5673
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)