


PROBLEM SUMMARY

Area
Paper Cup Machines
 Machine Id
PMC 1003 POS-215 (S/N 15962)
 Component
Circulating System
 Fluid
SUMMIT Syngear SH-1032 320 (85 GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY

No relevant graphs to display


RECOMMENDATION

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. (Customer Sample Comment: Cs)

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ATTENTION	ABNORMAL
Silt	scalar	*Visual	NONE	▲ MODER	NONE	▲ MODER
Appearance	scalar	*Visual	NORML	▲ HAZY	NORML	▲ SOLID
Free Water	scalar	*Visual		▲ 10.0	NEG	1.0

Customer Id: DARDALTX
Sample No.: TO50001690
Lab Number: 05873185
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off	MISSED	Sep 01 2023	?	We advise that you follow the water drain-off procedure for this component.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.
Check Water Access	MISSED	Sep 01 2023	?	We advise that you check for the source of water entry.

HISTORICAL DIAGNOSIS

14 Dec 2022 Diag: Don Baldrige

DIRT



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. Elemental level of silicon (Si) above normal. The condition of the oil is acceptable for the time in service.

[view report](#)



28 Nov 2022 Diag: Doug Bogart

SEDIMENT



We advise that you follow the water drain-off procedure for this component to remove more dense oil layer. We advise an early resample to confirm this situation. All component wear rates are normal. Appearance is layered. There is a moderate amount of visible silt present in the sample. The AN level is acceptable for this fluid.

[view report](#)



25 Oct 2022 Diag: Don Baldrige

DIRT




No corrective action is recommended at this time. Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample. Moderate concentration of visible metal present. All component wear rates are normal. There is no indication of any contamination in the oil. Silicon noted. The condition of the oil is acceptable for the time in service.

[view report](#)



Area
Paper Cup Machines
 Machine Id
PMC 1003 POS-215 (S/N 15962)
 Component
Circulating System
 Fluid
SUMMIT Syngear SH-1032 320 (85 GAL)



DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. (Customer Sample Comment: Cs)

Wear

All component wear rates are normal.

Contamination

Excessive free water present. There is a moderate amount of visible silt present in the sample.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	TO50001690	TO50001376	TO50001195
Sample Date	Client Info	09 Jun 2023	14 Dec 2022	28 Nov 2022
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	Filtered	N/A
Sample Status		ABNORMAL	ATTENTION	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184	26	21	22
Iron	ppm	91	84	75
Chromium	ppm	<1	<1	<1
Nickel	ppm	9	0	0
Titanium	ppm	<1	0	0
Silver	ppm	0	<1	0
Aluminum	ppm	2	3	2
Lead	ppm	<1	<1	0
Copper	ppm	2	2	2
Tin	ppm	<1	<1	<1
Vanadium	ppm	0	0	0
Cadmium	ppm	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	21	26	26
Barium	ppm	0	0	0
Molybdenum	ppm	0	0	0
Manganese	ppm	1	1	1
Magnesium	ppm	<1	0	0
Calcium	ppm	2	5	<1
Phosphorus	ppm	454	446	439
Zinc	ppm	10	10	13
Sulfur	ppm	6119	6140	6050






CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	4141	▲ 4838	4367
Sodium	ppm	6	6	7
Potassium	ppm	2	0	0
Water	%	0.085	---	0.044
ppm Water	ppm	850	---	440

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	0.72	---	---


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	▲ MODER
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ HAZY	▲ SOLID
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	0.2%	NEG	0.2%
Free Water	scalar	*Visual	▲ 10.0	NEG	1.0

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	326	287	286
Visc @ 100°C	cSt	ASTM D445	33.4	28.6	29.3
Viscosity Index (VI)	Scale	ASTM D2270	145	133	138

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO50001690 **Received** : 14 Jun 2023
Lab Number : **05873185** **Diagnosed** : 15 Jun 2023
Unique Number : 10512969 **Diagnostician** : Doug Bogart
Test Package : IND 2 (Additional Tests: KF, KV100, PQ, PrtCount, VI)

DART CONTAINER CORPORATION
 4444 W LEADBETTER DR
 DALLAS, TX
 US 75236
 Contact: YON PALOMINO
 yon.palomino@dart.biz
 T: (214)775-5673
 F:

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)