


PROBLEM SUMMARY

Sample Rating Trend




WEAR




Machine Id
KAESER SK 20 3765919 (S/N 1492)
Component
Compressor
Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY


▲ Non-ferrous Metals



▲ Viscosity @ 40°C



▲ Particle Trend



RECOMMENDATION

The filter change at the time of sampling has been noted. We advise that you inspect for the source(s) of wear. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	ABNORMAL	NORMAL
Copper	ppm	ASTM D5185m >50	▲ 215	0	2
Particles >6µm		ASTM D7647 >1300	▲ 2815	---	664
Particles >14µm		ASTM D7647 >80	▲ 309	---	61
Particles >21µm		ASTM D7647 >20	▲ 76	---	20
Oil Cleanliness		ISO 4406 (c) >--/17/13	▲ 20/19/15	---	20/17/13
Visc @ 40°C	cSt	ASTM D445 45	▲ 59.1	45.2	44.3

Customer Id: ATCFRE
Sample No.: KCPA001873
Lab Number: 05874478
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Inspect Wear Source	MISSED	Dec 20 2023	?	We advise that you inspect for the source(s) of wear.

HISTORICAL DIAGNOSIS

VIS DEBRIS



28 Mar 2023 Diag: Don Baldrige

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



NORMAL



01 Aug 2022 Diag: Don Baldrige

Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



ISO



08 Nov 2021 Diag: Don Baldrige


No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id
KAESER SK 20 3765919 (S/N 1492)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

- ▲ Recommendation**
 The filter change at the time of sampling has been noted. We advise that you inspect for the source(s) of wear. We recommend an early resample in 500 hours to monitor this condition.
- ▲ Wear**
 The copper level is severe.
- ▲ Contamination**
 There is a high amount of particulates present in the oil.
- ▲ Fluid Condition**
 The oil viscosity is higher than normal. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KCPA001873	KCPA000181	KCP49793
Sample Date	Client Info		24 May 2023	28 Mar 2023	01 Aug 2022
Machine Age	hrs	Client Info	99999	99999	96989
Oil Age	hrs	Client Info	0	0	4861
Oil Changed	Client Info		N/A	N/A	Not Changd
Sample Status			SEVERE	ABNORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	2	0	<1
Chromium	ppm	ASTM D5185m >10	<1	0	0
Nickel	ppm	ASTM D5185m >3	<1	0	0
Titanium	ppm	ASTM D5185m >3	<1	0	0
Silver	ppm	ASTM D5185m >2	0	0	<1
Aluminum	ppm	ASTM D5185m >10	<1	<1	2
Lead	ppm	ASTM D5185m >10	3	0	0
Copper	ppm	ASTM D5185m >50	▲ 215	0	2
Tin	ppm	ASTM D5185m >10	<1	0	<1
Antimony	ppm	ASTM D5185m	---	---	---
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	0	0	0
Barium	ppm	ASTM D5185m 90	0	76	8
Molybdenum	ppm	ASTM D5185m 0	<1	0	0
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m 100	39	85	42
Calcium	ppm	ASTM D5185m 0	13	2	<1
Phosphorus	ppm	ASTM D5185m 0	23	0	1
Zinc	ppm	ASTM D5185m 0	330	0	2
Sulfur	ppm	ASTM D5185m 23500	23240	22099	17291

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	2	<1	<1
Sodium	ppm	ASTM D5185m	7	20	8
Potassium	ppm	ASTM D5185m >20	3	0	2
Water	%	ASTM D6304 >0.05	0.025	0.015	0.018
ppm Water	ppm	ASTM D6304 >500	254.9	155.3	186.8

FLUID CLEANLINESS


	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		8003	---	5998
Particles >6µm	ASTM D7647	>1300	▲ 2815	---	664
Particles >14µm	ASTM D7647	>80	▲ 309	---	61
Particles >21µm	ASTM D7647	>20	▲ 76	---	20
Particles >38µm	ASTM D7647	>4	1	---	2
Particles >71µm	ASTM D7647	>3	0	---	1
Oil Cleanliness	ISO 4406 (c)	>--/17/13	▲ 20/19/15	---	20/17/13

FLUID DEGRADATION


	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	0.49	0.43	0.37

OIL ANALYSIS REPORT


Particle Trend




Water (KF)




Viscosity @ 40°C



Particle Trend




Acid Number








VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	LIGHT	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	▲ MODER	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	45	▲ 59.1	45.2	44.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA001873 **Received** : 15 Jun 2023
Lab Number : 05874478 **Tested** : 20 Jun 2023
Unique Number : 10519581 **Diagnosed** : 20 Jun 2023 - Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, PrtCount)

ATCC/NCI
 4600 WEDGEWOOD BLVD STE H
 FREDERICK, MD
 US 21703
 Contact: W. GUTIERREZ
 wgutierrez@atcc.org
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)