

# **PROBLEM SUMMARY**

OV Sa

Sample Rating Trend

ISO


8369868 (S/N 1877)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

## **COMPONENT CONDITION SUMMARY**



#### RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status			ATTENTION					
Particles >14µm	ASTM D7647	>80	<b>105</b>					
Particles >21µm	ASTM D7647	>20	<b>26</b>					
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>19/17/14</b>					

Customer Id: AMACARTX Sample No.: KCPA003473 Lab Number: 05874531 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

# RECOMMENDED ACTIONS

There are no recommended actions for this sample.

# HISTORICAL DIAGNOSIS




# **OIL ANALYSIS REPORT**

# 8369868 (S/N 1877)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)



## **DIAGNOSIS**

#### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates present in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Jun2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA003473		
Sample Date		Client Info		14 Jun 2023		
Machine Age	hrs	Client Info		2929		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ATTENTION		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	<1		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	<1		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	16		
Tin	ppm		>10	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	90	0		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	100	8		
Calcium	ppm	ASTM D5185m	0	0		
Phosphorus	ppm	ASTM D5185m	0	0		
Zinc	ppm	ASTM D5185m	0	4		
Sulfur	ppm	ASTM D5185m	23500	20181		
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		3		
Potassium	ppm	ASTM D5185m	>20	<1		
Water	%	ASTM D6304	>0.05	0.023		
ppm Water	ppm	ASTM D6304	>500	231.5		
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3023		
Particles >6μm		ASTM D7647	>1300	1063		
Particles >14µm		ASTM D7647	>80	<b>105</b>		
Particles >21µm		ASTM D7647	>20	<u>^</u> 26		
Particles >38µm		ASTM D7647	>4	0		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	▲ 19/17/14		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
	ma VOI I/a	ACTM DODAE	1.0	0.21		


Acid Number (AN)

mg KOH/g ASTM D8045 1.0

0.31



# **OIL ANALYSIS REPORT**







Certificate L2367

Sample No. Lab Number **Unique Number** 

: 05874531

: KCPA003473 : 10519634

Received Diagnosed

: 17 Jun 2023

Diagnostician : Don Baldridge Test Package : IND 2 ( Additional Tests: KF, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

4121 INTERNATIONAL CARROLLTON, TX US 75006

Contact: Service Manager