

PROBLEM SUMMARY

Sample Rating Trend


ISO

Machine Id KAESER BSD 50 6373479 (S/N 1086)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS										
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL					
Particles >6µm	ASTM D7647	>1300	4399		△ 9912					
Particles >14µm	ASTM D7647	>80	728		▲ 767					
Particles >21µm	ASTM D7647	>20	^ 257		<u>^</u> 226					
Particles >38μm	ASTM D7647	>4	1 0		▲ 13					
Oil Cleanliness	ISO 4406 (c)	>/17/13	<u>^</u> 20/19/17		<u>22/20/17</u>					

Customer Id: EASRAL Sample No.: KCPA005471 Lab Number: 05876263 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

01 Dec 2022 Diag: Don Baldridge

VIS DEBRIS



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



22 Jun 2022 Diag: Don Baldridge

150



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



07 Mar 2022 Diag: Don Baldridge

VIS DEBRIS




No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



KAESER BSD 50 6373479 (S/N 1086)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Apr2019	Jan2020 Jul2020	Nov2021 Jun2022	Jun2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA005471	KCP52347	KCP40483
Sample Date		Client Info		14 Jun 2023	01 Dec 2022	22 Jun 2022
Machine Age	hrs	Client Info		17937	16014	14377
Oil Age	hrs	Client Info		0	1637	1738
Oil Changed		Client Info		N/A	Not Changd	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	14	15	11
Tin	ppm	ASTM D5185m	>10	0	<1	<1
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	3
Barium	ppm	ASTM D5185m	90	2	0	<1
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	90	<1	4	14
Calcium	ppm	ASTM D5185m	2	0	<1	0
Phosphorus	ppm	ASTM D5185m		0	6	23
Zinc	ppm	ASTM D5185m		60	52	54
Sulfur	ppm	ASTM D5185m		18356	20777	18155
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		0	6	6
Potassium	ppm	ASTM D5185m	>20	1	2	2
Water	%	ASTM D6304	>0.05	0.007	0.012	0.036
ppm Water	ppm	ASTM D6304	>500	74.8	124.7	369.6
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		9898		33084
Particles >6µm		ASTM D7647	>1300	4399		△ 9912
Particles >14µm		ASTM D7647	>80	^ 728		<u>▲</u> 767
Particles >21µm		ASTM D7647	>20	<u> </u>		▲ 226
Particles >38μm		ASTM D7647	>4	<u> </u>		▲ 13
5		ASTM D7647	>3	0		2
Particles >71µm		/ TO THE DIOTE	, 0	•		
Particles >/1µm Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>△</u> 20/19/17		<u>22/20/17</u>


0.36

mg KOH/g ASTM D8045 0.4

Contact/Location: SERVICE MANAGER ? - EASRAL



OIL ANALYSIS REPORT







Certificate L2367

Lab Number **Unique Number**

: 05876263

: 10521366

Diagnosed : 19 Jun 2023 Diagnostician : Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

RALEIGH, NC

US 27603

Contact: SERVICE MANAGER

T: F: