

## **FUEL REPORT**

#### **∩PT**

# Sample Rating Trend NORMAL

NORMAL

# KIOTI CX2510HST 91101 (S/N PA2UA0131)

Diesel Fuel

NOT GIVEN (--- GAL)

AG		

#### Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

#### Corrosion

All metal levels are normal indicating no corrosion in the system.

#### **Contaminants**

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel. The amount and size of particulates present in the system are acceptable.


#### **Fuel Condition**

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

			Jun <sup>2</sup> 023			
CAMPLE INCORN	ATION				111	1::
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KT0000220		
Sample Date		Client Info		07 Jun 2023		
Machine Age	hrs	Client Info		11		
Sample Status				NORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.847		
Fuel Color	text	*Visual Screen		Yllow		
ASTM Color	scalar	*ASTM D1500		L1.5		
Visc @ 40°C	cSt	ASTM D445		2.63		
Pensky-Martens Flash Point	°C	*PMCC Calculated		55		
SULFUR CONTE	NΤ	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		10		
Sulfur (UVF)	ppm	ASTM D5453		10		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		154		
5% Distillation Point	°C	ASTM D86		184		
10% Distill Point	°C	ASTM D86		198		
15% Distillation Point	°C	ASTM D86		210		
20% Distill Point	°C	ASTM D86		219		
30% Distill Point	°C	ASTM D86		236		
40% Distill Point	°C	ASTM D86		251		
50% Distill Point	°C	ASTM D86		264		
60% Distill Point	°C	ASTM D86		278		
70% Distill Point	°C	ASTM D86		291		
80% Distill Point	°C	ASTM D86		307		
85% Distillation Point	°C	ASTM D86		315		
90% Distill Point	°C	ASTM D86		326		
95% Distillation Point	°C	ASTM D86		343		
Final Boiling Point	°C	ASTM D86		352		
Distillation Residue	%	ASTM D86		1.4		
Distillation Loss	%	ASTM D86		0.8		
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777		35.6		
Cetane Index		ASTM D4737	<40.0	46.4		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	< 0.1	0		
Potassium	ppm	ASTM D5185m	<0.1	0		
Water	%	ASTM D6304	< 0.05	0.003		
ppm Water	ppm	ASTM D6304	<500	38.0		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		
	, -					



### **FUEL REPORT**







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

: KT0000220 : 05876355

: 10521458

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Recieved : 16 Jun 2023 Diagnosed : 22 Jun 2023 Diagnostician : Doug Bogart

Test Package : DF-2 ( Additional Tests: Screen ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**CCR SALES AND SERVICE** 

70 UPPER MAIN ST ESSEX JUNCTION, VT US 05452

Contact: C. CRARY ccrary@ccrsalesvt.com T: (802)872-2666

Contact/Location: C. CRARY - CCRESS