




# PROBLEM SUMMARY

Sample Rating Trend

ISO




Area  
**Fermentation**  
 Machine Id  
**Lightnin FFG40MB01 Main Fermentor, Agitator**  
 Component  
**Gearbox**  
 Fluid  
**JAX FGG-AW ISO 220 (28 GAL)**



## COMPONENT CONDITION SUMMARY

### ▲ Particle Trend



## RECOMMENDATION

No corrective action is recommended at this time.  
 Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

Sample Status			ATTENTION	NORMAL	NORMAL
Particles >4µm	ASTM D7647	>20000	▲ 37942	11802	16821
Particles >6µm	ASTM D7647	>5000	▲ 6916	1714	2642
Oil Cleanliness	ISO 4406 (c)	>21/19/16	▲ 22/20/15	21/18/13	21/19/13

Customer Id: NOVFRANC  
 Sample No.: WC0793891  
 Lab Number: 05878080  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

*There are no recommended actions for this sample.*

## HISTORICAL DIAGNOSIS

### 15 Mar 2023 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 06 Dec 2022 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



### 15 Sep 2022 Diag: Angela Borella

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area

## Fermentation

Machine Id

### Lightnin FFG40MB01 Main Fermentor, Agitator

Component

#### Gearbox

Fluid

#### JAX FGG-AW ISO 220 (28 GAL)

#### DIAGNOSIS

##### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

##### Wear

All component wear rates are normal.

##### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

##### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

#### SAMPLE INFORMATION

	method	limit/base	current	history 1	history 2
Sample Number	Client Info		<b>WC0793891</b>	WC0697850	WC0663732
Sample Date	Client Info		<b>16 Jun 2023</b>	15 Mar 2023	06 Dec 2022
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ATTENTION</b>	NORMAL	NORMAL

#### WEAR METALS

	method	limit/base	current	history 1	history 2	
Iron	ppm	ASTM D5185m	>200	<b>8</b>	13	13
Chromium	ppm	ASTM D5185m	>15	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	>15	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>25	<b>1</b>	2	2
Lead	ppm	ASTM D5185m	>100	<b>0</b>	0	0
Copper	ppm	ASTM D5185m	>200	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D5185m	>25	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0

#### ADDITIVES

	method	limit/base	current	history 1	history 2	
Boron	ppm	ASTM D5185m		<b>&lt;1</b>	2	3
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>0</b>	0	0
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>&lt;1</b>	0	2
Calcium	ppm	ASTM D5185m		<b>5</b>	6	8
Phosphorus	ppm	ASTM D5185m		<b>581</b>	598	599
Zinc	ppm	ASTM D5185m		<b>2</b>	11	16
Sulfur	ppm	ASTM D5185m		<b>752</b>	808	613

#### CONTAMINANTS

	method	limit/base	current	history 1	history 2	
Silicon	ppm	ASTM D5185m	>50	<b>5</b>	5	4
Sodium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	0	0
Water	%	ASTM D6304	>0.2	<b>0.003</b>	0.006	0.005
ppm Water	ppm	ASTM D6304	>2000	<b>34.0</b>	65.7	52.4

#### FLUID CLEANLINESS






	method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647	>20000	<b>▲ 37942</b>	11802	16821
Particles >6µm	ASTM D7647	>5000	<b>▲ 6916</b>	1714	2642
Particles >14µm	ASTM D7647	>640	<b>185</b>	58	62
Particles >21µm	ASTM D7647	>160	<b>39</b>	14	11
Particles >38µm	ASTM D7647	>40	<b>1</b>	1	2
Particles >71µm	ASTM D7647	>10	<b>0</b>	0	1
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<b>▲ 22/20/15</b>	21/18/13	21/19/13

#### FLUID DEGRADATION

	method	limit/base	current	history 1	history 2	
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.60</b>	0.59	0.65




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	220	218	217

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
---------------	--------	------------	---------	-----------	-----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0793891 **Received** : 20 Jun 2023  
**Lab Number** : 05878080 **Diagnosed** : 21 Jun 2023  
**Unique Number** : 10523183 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**NOVOZYMES**  
 P.O. BOX 576, 77 PERRY CHAPEL CHURCH ROAD  
 FRANKLINTON, NC  
 US 27525  
 Contact: BRUCE THOMAS  
 brct@novozymes.com  
 T: (919)494-3146  
 F: (919)494-3456

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)