




# PROBLEM SUMMARY

Area  
**Formulation-FHG**  
 Machine Id  
**Sew Euro Drive FHG50CB01 Standardization Tank, Agitator**  
 Component  
**Gearbox**  
 Fluid  
**JAX FGG-AW ISO 220 (--- GAL)**

Sample Rating Trend



## COMPONENT CONDITION SUMMARY

No relevant graphs to display


### RECOMMENDATION

We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor.

### PROBLEMATIC TEST RESULTS

Sample Status		ABNORMAL	ABNORMAL	ABNORMAL
Appearance	scalar *Visual	NORML	▲ HAZY	▲ HAZY
Free Water	scalar *Visual	▲ 1.0	NEG	NEG

**Customer Id:** NOVFRANC  
**Sample No.:** WC0793881  
**Lab Number:** 05878083  
**Test Package:** IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component.

## HISTORICAL DIAGNOSIS

### 25 Oct 2022 Diag: Angela Borella

#### CONTAMINANT



If applicable; we advise that you use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



### 25 Oct 2021 Diag: Jonathan Hester

#### CONTAMINANT



We recommend you service the filters on this component. Resample at the next service interval to monitor. All component wear rates are normal. Appearance is hazy. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



### 15 Oct 2021 Diag: Doug Bogart

#### CONTAMINANT



We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


[view report](#)





# OIL ANALYSIS REPORT

Sample Rating Trend



**WATER**



Area

**Formulation-FHG**

Machine Id

**Sew Euro Drive FHG50CB01 Standardization Tank, Agitator**

Component

**Gearbox**

Fluid

**JAX FGG-AW ISO 220 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### ▲ Contamination

Free water present. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0793881</b>	WC0737318	WC0623652
Sample Date	Client Info		<b>15 Jun 2023</b>	25 Oct 2022	25 Oct 2021
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >200	<b>90</b>	165	100
Chromium	ppm	ASTM D5185m >15	<b>&lt;1</b>	2	1
Nickel	ppm	ASTM D5185m >15	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >25	<b>&lt;1</b>	1	<1
Lead	ppm	ASTM D5185m >100	<b>0</b>	0	<1
Copper	ppm	ASTM D5185m >200	<b>&lt;1</b>	0	<1
Tin	ppm	ASTM D5185m >25	<b>0</b>	0	0
Antimony	ppm	ASTM D5185m >5	<b>---</b>	---	0
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Calcium	ppm	ASTM D5185m	<b>0</b>	<1	<1
Phosphorus	ppm	ASTM D5185m	<b>592</b>	658	627
Zinc	ppm	ASTM D5185m	<b>0</b>	2	1
Sulfur	ppm	ASTM D5185m	<b>637</b>	722	570

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>2</b>	2	2
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Potassium	ppm	ASTM D5185m >20	<b>0</b>	0	0
Water	%	ASTM D6304 >0.2	<b>0.096</b>	0.025	0.145
ppm Water	ppm	ASTM D6304 >2000	<b>960</b>	256.9	1450

## FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	<b>2627</b>	---	▲ 164924
Particles >6µm	ASTM D7647	>5000	<b>1431</b>	---	▲ 26478
Particles >14µm	ASTM D7647	>640	<b>244</b>	---	▲ 1084
Particles >21µm	ASTM D7647	>160	<b>82</b>	---	▲ 215
Particles >38µm	ASTM D7647	>40	<b>13</b>	---	3
Particles >71µm	ASTM D7647	>10	<b>1</b>	---	0
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<b>19/18/15</b>	---	▲ 25/22/17

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.61</b>	0.70	0.703



# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	NONE	
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
Precipitate	scalar	*Visual	NONE	NONE	NONE	
Silt	scalar	*Visual	NONE	NONE	NONE	
Debris	scalar	*Visual	NONE	<b>LIGHT</b>	▲ MODER	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
Appearance	scalar	*Visual	NORML	▲ <b>HAZY</b>	▲ HAZY	▲ HAZY
Odor	scalar	*Visual	NORML	NORML	NORML	
Emulsified Water	scalar	*Visual	>0.2	<b>0.2%</b>	NEG	0.2%
Free Water	scalar	*Visual		▲ <b>1.0</b>	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	220	<b>219</b>	206	209

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0793881 **Received** : 20 Jun 2023  
**Lab Number** : **05878083** **Diagnosed** : 21 Jun 2023  
**Unique Number** : 10523186 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**NOVOZYMES**  
 P.O. BOX 576, 77 PERRY CHAPEL CHURCH ROAD  
 FRANKLINTON, NC  
 US 27525  
 Contact: BRUCE THOMAS  
 brct@novozymes.com  
 T: (919)494-3146  
 F: (919)494-3456

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)