


PROBLEM SUMMARY

KAESER SM 10 6255437 (S/N 1089)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status		ATTENTION	NORMAL	ABNORMAL					
Particles >6µm	ASTM D7647 >1300	<u> </u>	839	▲ 10612					
Oil Cleanliness	ISO 4406 (c) >/17/	13 🔺 19/18/13	17/13	2 1/14					


Customer Id: FALAKR Sample No.: KC106140 Lab Number: 05878990 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



RECOMMENDED /	ECOMMENDED ACTIONS					
Action	Status	Date	Done By	Description		
Change Fluid			?	Oil and filter change at the time of sampling has been noted.		
Change Filter			?	Oil and filter change at the time of sampling has been noted.		

HISTORICAL DIAGNOSIS



12 Apr 2021 Diag: Don Baldridge

Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



02 Jun 2020 Diag: Don Baldridge



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

02 Dec 2019 Diag: Jonathan Hester



We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report





OIL ANALYSIS REPORT

KAESER SM 10 6255437 (S/N 1089)

Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number		Client Info		KC106140	KC79138	KC78685
Sample Date		Client Info		14 Jun 2023	12 Apr 2021	02 Jun 2020
Machine Age	hrs	Client Info		4582	2507	1907
Oil Age	hrs	Client Info		2075	600	1150
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ATTENTION	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	<1
Nickel	ppm	ASTM D5185m	>3	0	0	2
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m		3	1	0
Tin	ppm	ASTM D5185m	>10	0	<1	<1
Antimony	ppm	ASTM D5185m	~10		0	0
Vanadium		ASTM D5185m		0	0	<1
	ppm			0	0	
Cadmium	ppm	ASTM D5185m		U	0	<1
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m		0	<1	1
Barium	ppm	ASTM D5185m	90	2	3	0
Molybdenum	ppm	ASTM D5185m		0	0	<1
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	90	47	74	0
Calcium	ppm	ASTM D5185m	2	<1	2	<1
Phosphorus	ppm	ASTM D5185m		0	<1	0
Zinc	ppm	ASTM D5185m		3	0	0
CONTAMINANTS	6	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	4	13	0
Sodium	ppm	ASTM D5185m		17	20	27
Potassium	ppm	ASTM D5185m	>20	3	2	1
Water	%	ASTM D6304	>0.05	0.013	0.022	0.026
ppm Water	ppm	ASTM D6304	>500	135.9	228.7	262.7
FLUID CLEANLIN	NESS	method	limit/base	current	history 1	history 2
Particles >4µm		ASTM D7647		4492	2609	26121
Particles >6µm		ASTM D7647	>1300	<u> </u>	839	▲ 10612
Particles >14µm		ASTM D7647	>80	77	50	9 4
Particles >21µm		ASTM D7647		17	13	▲ 20
Particles >38µm		ASTM D7647	>4	1	0	0
Particles >71µm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	▲ 19/18/13	17/13	▲ 21/14
FLUID DEGRADA		method	limit/base	current	history 1	history 2
						0.296
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.31	0.302	0.290

Contact/Location: Service Manager - FALAKR



OIL ANALYSIS REPORT

limit/base

NONE

NONE

NONE

NONE


current


NONE

NONE

NONE

NONE





history 1

NONE

NONE

NONE

NONE


history 2

VLITE

NONE

NONE

NONE



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - FALAKR