

PROBLEM SUMMARY

Sample Rating Trend

ISO


7997647 (S/N 1034)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	ABNORMAL					
Particles >6µm	ASTM D7647	>1300	12445	▲ 3069					
Particles >14μm	ASTM D7647	>80	254	▲ 122					
Particles >21µm	ASTM D7647	>20	<u></u> 61	△ 30					
Oil Cleanliness	ISO 4406 (c)	>/17/13	23/21/15	21/19/14					

Customer Id: VEKMOR Sample No.: KCPA001717 Lab Number: 05878994 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

23 Jun 2022 Diag: Doug Bogart

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. We were unable to perform a particle count on this sample. We recommend an early resample in 500 hours to monitor this condition. All component wear rates are normal. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

7997647 (S/N 1034)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Sample Rating Trend



DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jun 2022	Jun2023		
SAMPLE INFORM	MATION	method	limit/base	current	history 1	history 2
Sample Number		Client Info		KCPA001717	KCP49635	
Sample Date		Client Info		19 Jun 2023	23 Jun 2022	
Machine Age	hrs	Client Info		0	3160	
Oil Age	hrs	Client Info		0	3160	
Oil Changed		Client Info		N/A	Not Changd	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m	>50	7	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	2	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m	>50	5	9	
Tin	ppm	ASTM D5185m	>10	<1	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m	0	0	2	
Barium	ppm	ASTM D5185m	90	5	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	100	51	26	
Calcium	ppm	ASTM D5185m	0	0	0	
Phosphorus	ppm	ASTM D5185m	0	<1	5	
Zinc	ppm	ASTM D5185m	0	32	56	
Sulfur	ppm	ASTM D5185m	23500	20575	17694	
CONTAMINANTS	3	method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	>25	2	0	
Sodium	ppm	ASTM D5185m		11	9	
Potassium	ppm	ASTM D5185m	>20	6	12	
Water	%	ASTM D6304	>0.05	0.027	0.022	
ppm Water	ppm	ASTM D6304	>500	278.2	223.3	
FLUID CLEANLIN	IESS	method	limit/base	current	history 1	history 2
Particles >4μm		ASTM D7647		70181	13589	
Particles >6µm		ASTM D7647	>1300	<u> </u>	△ 3069	
Particles >14μm		ASTM D7647	>80	<u>^</u> 254	<u>▲</u> 122	
Particles >21μm		ASTM D7647	>20	<u></u> 61	△ 30	
Particles >38μm		ASTM D7647	>4	3	3	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	23/21/15	<u>^</u> 21/19/14	
FLUID DEGRADA	ATION	method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.43	0.39	



OIL ANALYSIS REPORT





Certificate L2367

Sample No. Lab Number **Unique Number**

: KCPA001717 : 05878994

: 10524097

Received Diagnosed

: 22 Jun 2023

Diagnostician : Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) 90 CERAMIC TILE DR MORGANTON, NC US 28655

Contact: Service Manager

T:

F: