




# FUEL REPORT

Sample Rating Trend



ISO



Machine Id  
**Kohler 80kw**  
 Component  
**Diesel Fuel**  
 Fluid  
**NOT GIVEN (650 GAL)**

## DIAGNOSIS

### Recommendation

Recommend pre-filtering before use. All laboratory tests indicate that this sample meets specifications for No.2 low-sulfur diesel fuel.

### Corrosion

All metal levels are normal indicating no corrosion in the system.

### Contaminants

There is a high amount of particulates present in the fuel. The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample.

### Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

SAMPLE INFORMATION		method	limit/base	current	history 1	history 2
Sample Number	Client Info			<b>WC0829178</b>	WC0658741	---
Sample Date	Client Info			<b>13 Jun 2023</b>	01 Feb 2022	---
Machine Age	hrs	Client Info		<b>737</b>	0	---
Sample Status				<b>MARGINAL</b>	ATTENTION	---

PHYSICAL PROPERTIES		method	limit/base	current	history 1	history 2
Specific Gravity		*ASTM D1298		<b>0.843</b>	0.843	---
Fuel Color	text	*Visual Screen		<b>Red</b>	Red	---
ASTM Color	scalar	*ASTM D1500		<b>1.0</b>	L4.0	---
Visc @ 40°C	cSt	ASTM D445		<b>2.53</b>	2.56	---
Pensky-Martens Flash Point	°C	*PMCC Calculated		<b>65</b>	65	---
Cloud Point	°C	ASTM D5771		<b>-13</b>	-13	---
Pour Point	°C	ASTM D5950		<b>-35</b>	-37	---

SULFUR CONTENT		method	limit/base	current	history 1	history 2
Sulfur	ppm	ASTM D5185m		<b>467</b>	370	---
Sulfur (UVF)	ppm	ASTM D5453		<b>367</b>	425	---





DISTILLATION		method	limit/base	current	history 1	history 2
Initial Boiling Point	°C	ASTM D86		<b>170</b>	169	---
5% Distillation Point	°C	ASTM D86		<b>191</b>	193	---
10% Distill Point	°C	ASTM D86		<b>202</b>	203	---
15% Distillation Point	°C	ASTM D86		<b>211</b>	211	---
20% Distill Point	°C	ASTM D86		<b>219</b>	219	---
30% Distill Point	°C	ASTM D86		<b>233</b>	234	---
40% Distill Point	°C	ASTM D86		<b>247</b>	248	---
50% Distill Point	°C	ASTM D86		<b>260</b>	261	---
60% Distill Point	°C	ASTM D86		<b>274</b>	274	---
70% Distill Point	°C	ASTM D86		<b>288</b>	288	---
80% Distill Point	°C	ASTM D86		<b>303</b>	303	---
85% Distillation Point	°C	ASTM D86		<b>312</b>	312	---
90% Distill Point	°C	ASTM D86		<b>323</b>	323	---
95% Distillation Point	°C	ASTM D86		<b>339</b>	339	---
Final Boiling Point	°C	ASTM D86		<b>348</b>	350	---
Distillation Residue	%	ASTM D86		<b>1.4</b>	1.4	---
Distillation Loss	%	ASTM D86		<b>0.8</b>	0.5	---

IGNITION QUALITY		method	limit/base	current	history 1	history 2
API Gravity		ASTM D7777		<b>36.4</b>	36.4	---
Cetane Index		ASTM D4737	<40.0	<b>47.5</b>	47.4	---

CONTAMINANTS		method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m	<1.0	<b>0</b>	0	---
Sodium	ppm	ASTM D5185m	<0.1	<b>0</b>	0	---
Potassium	ppm	ASTM D5185m	<0.1	<b>&lt;1</b>	0	---
Water	%	ASTM D6304	<0.05	<b>0.003</b>	0.003	---
ppm Water	ppm	ASTM D6304	<500	<b>30.7</b>	35.1	---
% Gasoline	%	*In-House	<0.50	<b>0.0</b>	0.0	---
% Biodiesel	%	*In-House	<20.0	<b>0.0</b>	0.0	---



# FUEL REPORT



FLUID CLEANLINESS	method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647	>2500	▲ 14150	---	---
Particles >6µm	ASTM D7647	>640	▲ 4750	---	---
Particles >14µm	ASTM D7647	>80	▲ 410	---	---
Particles >21µm	ASTM D7647	>20	▲ 106	---	---
Particles >38µm	ASTM D7647	>4	2	---	---
Particles >71µm	ASTM D7647	>3	0	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 21/19/16	---	---


HEAVY METALS	method	limit/base	current	history 1	history 2
Aluminum	ppm	ASTM D5185m <0.1	0	<1	---
Nickel	ppm	ASTM D5185m <0.1	<1	0	---
Lead	ppm	ASTM D5185m <0.1	0	0	---
Vanadium	ppm	ASTM D5185m <0.1	0	0	---
Iron	ppm	ASTM D5185m <0.1	0	0	---
Calcium	ppm	ASTM D5185m <0.1	0	1	---
Magnesium	ppm	ASTM D5185m <0.1	0	0	---
Phosphorus	ppm	ASTM D5185m <0.1	1	7	---
Zinc	ppm	ASTM D5185m <0.1	0	0	---

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
Color					
Bottom					

no image

no image

### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0829178 **Received** : 21 Jun 2023  
**Lab Number** : 05880410 **Diagnosed** : 05 Jul 2023  
**Unique Number** : 10525513 **Diagnostician** : Doug Bogart  
**Test Package** : DF-3 ( Additional Tests: Screen )

**ALTERNATIVE POWER**  
 1000 NORTHGATE CT  
 MORRISVILLE, NC  
 US 27560  
 Contact: ROBERT MCARTHUR  
 rmcarthur@bittingelectric.com  
 T: (919)467-9417  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)