



# OIL ANALYSIS REPORT

Sample Rating Trend



ISO

Area  
**COWAN**  
 Machine Id  
**COWAN 224534**  
 Component  
**Front Differential**  
 Fluid  
**NOT GIVEN (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history 1	history 2
Sample Number	Client Info	<b>WC0828684</b>	---	---
Sample Date	Client Info	<b>24 May 2023</b>	---	---
Machine Age	mls	Client Info	<b>102</b>	---
Oil Age	mls	Client Info	<b>0</b>	---
Oil Changed	Client Info	<b>N/A</b>	---	---
Sample Status		<b>ABNORMAL</b>	---	---

## WEAR METALS

method	limit/base	current	history 1	history 2
Iron	ppm	ASTM D5185m >500	<b>22</b>	---
Chromium	ppm	ASTM D5185m >10	<b>&lt;1</b>	---
Nickel	ppm	ASTM D5185m >10	<b>&lt;1</b>	---
Titanium	ppm	ASTM D5185m	<b>0</b>	---
Silver	ppm	ASTM D5185m	<b>0</b>	---
Aluminum	ppm	ASTM D5185m >25	<b>0</b>	---
Lead	ppm	ASTM D5185m >25	<b>&lt;1</b>	---
Copper	ppm	ASTM D5185m >100	<b>2</b>	---
Tin	ppm	ASTM D5185m >10	<b>1</b>	---
Vanadium	ppm	ASTM D5185m	<b>0</b>	---
Cadmium	ppm	ASTM D5185m	<b>0</b>	---

## ADDITIVES

method	limit/base	current	history 1	history 2
Boron	ppm	ASTM D5185m	<b>277</b>	---
Barium	ppm	ASTM D5185m	<b>3</b>	---
Molybdenum	ppm	ASTM D5185m	<b>0</b>	---
Manganese	ppm	ASTM D5185m	<b>3</b>	---
Magnesium	ppm	ASTM D5185m	<b>0</b>	---
Calcium	ppm	ASTM D5185m	<b>4</b>	---
Phosphorus	ppm	ASTM D5185m	<b>1525</b>	---
Zinc	ppm	ASTM D5185m	<b>0</b>	---
Sulfur	ppm	ASTM D5185m	<b>32687</b>	---

## CONTAMINANTS

method	limit/base	current	history 1	history 2
Silicon	ppm	ASTM D5185m >75	<b>22</b>	---
Sodium	ppm	ASTM D5185m	<b>7</b>	---
Potassium	ppm	ASTM D5185m >20	<b>3</b>	---
Water	%	ASTM D6304 >.2	<b>0.046</b>	---
ppm Water	ppm	ASTM D6304 >2000	<b>468.0</b>	---

## FLUID CLEANLINESS






method	limit/base	current	history 1	history 2
Particles >4µm	ASTM D7647 >20000	<b>▲ 129456</b>	---	---
Particles >6µm	ASTM D7647 >5000	<b>▲ 21838</b>	---	---
Particles >14µm	ASTM D7647 >640	<b>274</b>	---	---
Particles >21µm	ASTM D7647 >160	<b>39</b>	---	---
Particles >38µm	ASTM D7647 >40	<b>2</b>	---	---
Particles >71µm	ASTM D7647 >10	<b>1</b>	---	---
Oil Cleanliness	ISO 4406 (c) >21/19/16	<b>▲ 24/22/15</b>	---	---

## FLUID DEGRADATION

method	limit/base	current	history 1	history 2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>2.34</b>	---



# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history 1	history 2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>.2	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history 1	history 2
Visc @ 40°C	cSt	ASTM D445	98.9	---	---
Visc @ 100°C	cSt	ASTM D445	14.5	---	---
Viscosity Index (VI)	Scale	ASTM D2270	151	---	---

SAMPLE IMAGES	method	limit/base	current	history 1	history 2
Color				no image	no image
Bottom				no image	no image

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0828684 **Received** : 22 Jun 2023  
**Lab Number** : 05881475 **Diagnosed** : 30 Jun 2023  
**Unique Number** : 10526578 **Diagnostician** : Jonathan Hester  
**Test Package** : MOB 2 ( Additional Tests: KF, KV100, PrtCount, VI )

**BASF - GIANNA CREDAROLI**  
 500 WHITE PLAINS RD  
 TARRYTOWN, NY  
 US 10591  
 Contact: GIANNA CREDAROLI  
 gianna.credaroli@basf.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)