




OIL ANALYSIS REPORT

Sample Rating Trend

SEDIMENT

Area
WALPOLE
 Machine Id
943 - WALPOLE
 Component
Front Differential
 Fluid
NOT GIVEN (--- GAL)



DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of visible silt present in the sample.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0828702	WC0751724	---
Sample Date	Client Info		02 Jun 2023	13 Sep 2022	---
Machine Age	mls	Client Info	106319	799	---
Oil Age	mls	Client Info	0	0	---
Oil Changed	Client Info		N/A	N/A	---
Sample Status			ABNORMAL	ABNORMAL	---

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>500	303	37	---
Chromium	ppm	ASTM D5185m	>10	4	<1	---
Nickel	ppm	ASTM D5185m	>10	2	0	---
Titanium	ppm	ASTM D5185m		0	0	---
Silver	ppm	ASTM D5185m		0	0	---
Aluminum	ppm	ASTM D5185m	>25	4	<1	---
Lead	ppm	ASTM D5185m	>25	6	0	---
Copper	ppm	ASTM D5185m	>100	50	<1	---
Tin	ppm	ASTM D5185m	>10	7	<1	---
Vanadium	ppm	ASTM D5185m		0	0	---
Cadmium	ppm	ASTM D5185m		0	<1	---

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		67	77	---
Barium	ppm	ASTM D5185m		0	0	---
Molybdenum	ppm	ASTM D5185m		<1	0	---
Manganese	ppm	ASTM D5185m		7	7	---
Magnesium	ppm	ASTM D5185m		204	192	---
Calcium	ppm	ASTM D5185m		5	8	---
Phosphorus	ppm	ASTM D5185m		1823	1720	---
Zinc	ppm	ASTM D5185m		0	18	---
Sulfur	ppm	ASTM D5185m		31695	31075	---

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>75	34	19	---
Sodium	ppm	ASTM D5185m		3	5	---
Potassium	ppm	ASTM D5185m	>20	3	1	---
Water	%	ASTM D6304	>.2	0.030	0.040	---
ppm Water	ppm	ASTM D6304	>2000	302.2	406.5	---

FLUID CLEANLINESS





	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>20000	---	▲ 173968	---
Particles >6µm	ASTM D7647	>5000	---	▲ 65004	---
Particles >14µm	ASTM D7647	>640	---	540	---
Particles >21µm	ASTM D7647	>160	---	30	---
Particles >38µm	ASTM D7647	>40	---	2	---
Particles >71µm	ASTM D7647	>10	---	1	---
Oil Cleanliness	ISO 4406 (c)	>21/19/16	---	▲ 25/23/16	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045		0.46	0.52	---



OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	▲ MODER	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>.2	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	54.3	102	---
Visc @ 100°C	cSt	ASTM D445	9.9	15.0	---
Viscosity Index (VI)	Scale	ASTM D2270	170	153	---





SAMPLE IMAGES

	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0828702 **Received** : 22 Jun 2023
Lab Number : 05881490 **Diagnosed** : 20 Jul 2023
Unique Number : 10526593 **Diagnostician** : Doug Bogart
Test Package : MOB 2 (Additional Tests: KF, KV100, PrtCount, VI)

BASF - GIANNA CREDAROLI
 500 WHITE PLAINS RD
 TARRYTOWN, NY
 US 10591
 Contact: GIANNA CREDAROLI
 gianna.credaroli@basf.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)