

## **OIL ANALYSIS REPORT**

#### Sample Rating Trend



# TWIN\_U2 TWIN\_U2\_M2

**Non-Drive End Bearing** 

ROYAL PURPLE SYNFILM GT 32 (--- GAL)

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

The water content is negligible. There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0033008	RP0034756	RP0011479
Sample Date		Client Info		07 Jul 2023	08 Mar 2023	15 Jun 2021
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	<1	1	<1
Chromium	ppm	ASTM D5185m	>20	0	0	<1
Nickel	ppm	ASTM D5185m	>20	<1	<1	<1
Titanium	ppm	ASTM D5185m		0	0	<1
Silver	ppm	ASTM D5185m		0	0	4
Aluminum	ppm	ASTM D5185m	>20	<1	1	0
Lead	ppm	ASTM D5185m	>20	2	4	2
Copper	ppm	ASTM D5185m	>20	19	16	14
Tin	ppm	ASTM D5185m	>20	3	2	7
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	<1
Cadmium	ppm	ASTM D5185m		<1	<1	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	2
Barium	ppm	ASTM D5185m		2	0	<1
Molybdenum	ppm	ASTM D5185m		0	0	<1
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m		86	74	84
Calcium	ppm	ASTM D5185m		2	2	6
Phosphorus	ppm	ASTM D5185m		2	6	5
Zinc	ppm	ASTM D5185m		2	6	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	8	<b>2</b> 6	1
Sodium	ppm	ASTM D5185m		<1	0	<1
Potassium	ppm	ASTM D5185m	>20	<1	1	<1
Water	%	ASTM D6304	>2	0.023	0.034	0.038
ppm Water	ppm	ASTM D6304		235.3	346.4	387.9
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.415	0.369	0.286



# **OIL ANALYSIS REPORT**

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

>2

32

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

NEG

NEG

32.0

VLITE

NONE

NONE

NONE

VLITE

NONE

NORML

NORML

NEG

NEG

31.8

A MODER

NONE

NONE

NONE

NONE

NONE


NORML


NORML

NEG

NEG

32.4





Jun15/21,

2 0.10 -0.00 -

lu17/23

: 14 Jul 2023

: 18 Jul 2023



Unique Number : 10560025 Diagnostician : Jonathan Hester Test Package : IND 2 Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

## Jun15/21 unr22/21

: RP0033008

: 05898669

25

Laboratory

Sample No.

Lab Number

Mar8/23

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Received

Diagnosed

ASTON, PA

T: (610)220-8386

US 19014

F:

Mar8/23

144 CONCHESTER HIGHWAY

Contact: QUITA MORGAN

**ENERGY TRANSFER - TWIN OAKS** 

