




OIL ANALYSIS REPORT



Machine Id
COVM04BE (S/N GZJ00185)
 Component
Biogas Engine
 Fluid
CHEVRON HDAX 6500 LFG GAS ENGINE OIL (141 GAL)

Sample Rating Trend



NORMAL



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | WC0816098 | WC0618636 | WC0722601 |
| Sample Date | Client Info | | 10 Jul 2023 | 18 Apr 2023 | 10 Apr 2023 |
| Machine Age | hrs | Client Info | 124798 | 802067 | 124531 |
| Oil Age | hrs | Client Info | 124467 | 242 | 124467 |
| Oil Changed | Client Info | | Changed | Changed | Changed |
| Sample Status | | | NORMAL | NORMAL | NORMAL |

CONTAMINATION

| | method | limit/base | current | history1 | history2 |
|--------|-----------|------------|----------------|----------|----------|
| Fuel | WC Method | >4.0 | <1.0 | <1.0 | <1.0 |
| Glycol | WC Method | | NEG | NEG | NEG |

WEAR METALS

| | method | limit/base | current | history1 | history2 | |
|----------|--------|-------------|---------|--------------|----------|----|
| Iron | ppm | ASTM D5185m | >15 | 8 | 2 | <1 |
| Chromium | ppm | ASTM D5185m | >4 | <1 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >2 | <1 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m | >5 | 0 | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >6 | 2 | 1 | <1 |
| Lead | ppm | ASTM D5185m | >9 | <1 | 0 | <1 |
| Copper | ppm | ASTM D5185m | >6 | 2 | <1 | 2 |
| Tin | ppm | ASTM D5185m | >4 | 2 | <1 | 0 |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 | |
|------------|--------|-------------|---------|--------------|----------|------|
| Boron | ppm | ASTM D5185m | | 7 | 4 | 5 |
| Barium | ppm | ASTM D5185m | | 2 | 0 | <1 |
| Molybdenum | ppm | ASTM D5185m | | 7 | 6 | 7 |
| Manganese | ppm | ASTM D5185m | | <1 | 1 | <1 |
| Magnesium | ppm | ASTM D5185m | | 30 | 32 | 35 |
| Calcium | ppm | ASTM D5185m | | 1769 | 1489 | 1704 |
| Phosphorus | ppm | ASTM D5185m | | 281 | 253 | 275 |
| Zinc | ppm | ASTM D5185m | | 371 | 299 | 314 |
| Sulfur | ppm | ASTM D5185m | | 2462 | 1757 | 1896 |

CONTAMINANTS

| | method | limit/base | current | history1 | history2 | |
|-----------|--------|-------------|---------|--------------|----------|----|
| Silicon | ppm | ASTM D5185m | >181 | 102 | 87 | 36 |
| Sodium | ppm | ASTM D5185m | | <1 | <1 | 0 |
| Potassium | ppm | ASTM D5185m | >20 | 1 | 0 | 0 |

INFRA-RED




| | method | limit/base | current | history1 | history2 | |
|-----------|----------|-------------|---------|-------------|----------|------|
| Soot % | % | *ASTM D7844 | | 0.1 | 0 | 0 |
| Nitration | Abs/cm | *ASTM D7624 | >20 | 5.5 | 5.0 | 4.8 |
| Sulfation | Abs/.1mm | *ASTM D7415 | >30 | 17.6 | 15.6 | 15.5 |

FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 | |
|------------------|----------|-------------|---------|-------------|----------|------|
| Oxidation | Abs/.1mm | *ASTM D7414 | >25 | 10.2 | 9.9 | 8.8 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 1.2 | 0.72 | 0.72 | 0.59 |
| Base Number (BN) | mg KOH/g | ASTM D2896 | 4.5 | 5.47 | 4.92 | 6.73 |











OIL ANALYSIS REPORT



| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.1 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| Visc @ 100°C | cSt | ASTM D445 | 14.7 | 13.5 | 13.4 |

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0816098 **Received** : 14 Jul 2023
Lab Number : 05898741 **Diagnosed** : 17 Jul 2023
Unique Number : 10560097 **Diagnostician** : Don Baldrige
Test Package : MOB 2

EDL NA Recips-Covel
 COVEL GARDENS POWER STATION, 8611 COVEL ROAD
 SAN ANTONIO, TX
 US 78252
 Contact: ARIEL CARRION
 ariel.carrion@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)