




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
KENWORTH W900 2020 120 KW W900

Component
Diesel Engine

Fluid
TRC MOLY XL PRO-SPEC IV XP 15W40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			TR0000942	TR05827862	---
Sample Date	Client Info			30 Jun 2023	07 Apr 2023	---
Machine Age	mls	Client Info		424557	397038	---
Oil Age	mls	Client Info		45000	0	---
Oil Changed	Client Info			Changed	Not Changd	---
Sample Status				NORMAL	NORMAL	---

CONTAMINATION		method	limit/base	current	history1	history2
Fuel	WC Method	>5		<1.0	<1.0	---
Glycol	WC Method			NEG	NEG	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>100	80	63	---
Chromium	ppm	ASTM D5185m	>20	3	2	---
Nickel	ppm	ASTM D5185m	>4	<1	0	---
Titanium	ppm	ASTM D5185m		<1	0	---
Silver	ppm	ASTM D5185m	>3	0	0	---
Aluminum	ppm	ASTM D5185m	>20	10	4	---
Lead	ppm	ASTM D5185m	>40	11	4	---
Copper	ppm	ASTM D5185m	>330	5	6	---
Tin	ppm	ASTM D5185m	>15	2	<1	---
Vanadium	ppm	ASTM D5185m		<1	0	---
Cadmium	ppm	ASTM D5185m		0	0	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		4	0	---
Barium	ppm	ASTM D5185m		2	0	---
Molybdenum	ppm	ASTM D5185m		139	122	---
Manganese	ppm	ASTM D5185m		1	1	---
Magnesium	ppm	ASTM D5185m		62	67	---
Calcium	ppm	ASTM D5185m		5389	4645	---
Phosphorus	ppm	ASTM D5185m		1122	1004	---
Zinc	ppm	ASTM D5185m		1328	1157	---
Sulfur	ppm	ASTM D5185m		5354	4136	---



CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	8	8	---
Sodium	ppm	ASTM D5185m		4	2	---
Potassium	ppm	ASTM D5185m	>20	4	4	---

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	>3	1	0.8	---
Nitration	Abs/cm	*ASTM D7624	>20	18.6	15.9	---
Sulfation	Abs/.1mm	*ASTM D7415	>30	35.1	29.9	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	26.7	20.6	---
Base Number (BN)	mg KOH/g	ASTM D2896		12.05	12.04	---











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.2	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	17.7	16.2	---

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TR0000942 **Received** : 14 Jul 2023
Lab Number : 05898774 **Diagnosed** : 17 Jul 2023
Unique Number : 10560130 **Diagnostician** : Don Baldrige
Test Package : MOB 2

DIETERMAN FARM SERVICES
 11038 S BURKETT RD
 MARION, MI
 US 49665
 Contact: DALE DIETERMAN
 dietermanfarmservices@hotmail.com

To discuss this sample report, contact Customer Service at 1-800-827-0711.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: