




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
AG BAG INT X1114 PROFESSIONAL BAGGER 3 (S/N 4205178)

Component
Diesel Engine

Fluid
TRC MOLY XL PRO-SPEC IV 15W40 (11 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	TR0000941	TR05154033	TR04894747
Sample Date	Client Info	30 Jun 2023	22 Dec 2020	14 Jan 2020
Machine Age	hrs	3591	3325	3204
Oil Age	hrs	736	470	349
Oil Changed	Client Info	Changed	Not Changd	Not Changd
Sample Status		NORMAL	NORMAL	NORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Fuel	WC Method >5	<1.0	<1.0	<1.0
Glycol	WC Method	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >100	39	29	16
Chromium	ppm ASTM D5185m >6	<1	<1	<1
Nickel	ppm ASTM D5185m >4	<1	0	<1
Titanium	ppm ASTM D5185m >2	<1	<1	<1
Silver	ppm ASTM D5185m >2	0	0	0
Aluminum	ppm ASTM D5185m >30	4	2	3
Lead	ppm ASTM D5185m >10	1	<1	<1
Copper	ppm ASTM D5185m >150	8	7	3
Tin	ppm ASTM D5185m >4	<1	<1	<1
Antimony	ppm ASTM D5185m	---	0	0
Vanadium	ppm ASTM D5185m	<1	0	0
Cadmium	ppm ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	0	3	0
Barium	ppm ASTM D5185m	2	0	0
Molybdenum	ppm ASTM D5185m	124	132	120
Manganese	ppm ASTM D5185m	<1	<1	<1
Magnesium	ppm ASTM D5185m	80	125	115
Calcium	ppm ASTM D5185m 1300	4131	4070	3803
Phosphorus	ppm ASTM D5185m	852	889	811
Zinc	ppm ASTM D5185m 1300	1073	1017	856
Sulfur	ppm ASTM D5185m	4357	3656	4610

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >20	7	5	6
Sodium	ppm ASTM D5185m	3	3	4
Potassium	ppm ASTM D5185m >20	5	2	2

INFRA-RED



method	limit/base	current	history1	history2
Soot %	% *ASTM D7844 >3	0.4	0.4	0.2
Nitration	Abs/cm *ASTM D7624 >20	11.0	10.8	9.5
Sulfation	Abs/.1mm *ASTM D7415 >30	19.6	19	17.2

FLUID DEGRADATION

method	limit/base	current	history1	history2
Oxidation	Abs/.1mm *ASTM D7414 >25	11.8	11.6	10.4
Base Number (BN)	mg KOH/g ASTM D2896 14	16.10	11.7	15.3











OIL ANALYSIS REPORT



PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	15.5	12.6	13.2

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TR0000941 **Received** : 14 Jul 2023
Lab Number : 05898775 **Diagnosed** : 17 Jul 2023
Unique Number : 10560131 **Diagnostician** : Wes Davis
Test Package : MOB 2

DIETERMAN FARM SERVICES
 11038 S BURKETT RD
 MARION, MI
 US 49665
 Contact: DALE DIETERMAN
 dietermanfarmservices@hotmail.com

To discuss this sample report, contact Customer Service at 1-800-827-0711.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: