




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Area  
**[727114]**  
 Machine Id  
**TPX-3**  
 Component  
**Hydraulic System**  
 Fluid  
**FLEET SUPREME AW 46 (--- GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor. Please specify the component make and model with your next sample.

### Wear

All component wear rates are normal.

### Contamination

The system cleanliness is acceptable for your target ISO 4406 cleanliness code. The system and fluid cleanliness is acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0763507</b>	WC0611265	WC0763509
Sample Date	Client Info		<b>12 Jul 2023</b>	12 Apr 2023	09 Jan 2023
Machine Age	hrs	Client Info	<b>457</b>	430	379
Oil Age	hrs	Client Info	<b>100</b>	105	0
Oil Changed	Client Info		<b>Not Chngd</b>	Not Chngd	Not Chngd
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	<b>3</b>	3	2
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >10	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	0	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >10	<b>&lt;1</b>	0	0
Lead	ppm	ASTM D5185m >10	<b>&lt;1</b>	1	<1
Copper	ppm	ASTM D5185m >75	<b>5</b>	5	4
Tin	ppm	ASTM D5185m >10	<b>0</b>	<1	0
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	<b>10</b>	11	11
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Magnesium	ppm	ASTM D5185m	<b>4</b>	3	<1
Calcium	ppm	ASTM D5185m	<b>201</b>	133	124
Phosphorus	ppm	ASTM D5185m	<b>417</b>	381	376
Zinc	ppm	ASTM D5185m	<b>466</b>	469	448
Sulfur	ppm	ASTM D5185m	<b>1379</b>	1222	1299

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >20	<b>2</b>	2	2
Sodium	ppm	ASTM D5185m	<b>1</b>	0	<1
Potassium	ppm	ASTM D5185m >20	<b>0</b>	<1	0

## FLUID CLEANLINESS





	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>547</b>	---	1124
Particles >6µm	ASTM D7647	>1300	<b>109</b>	---	276
Particles >14µm	ASTM D7647	>160	<b>9</b>	---	38
Particles >21µm	ASTM D7647	>40	<b>2</b>	---	14
Particles >38µm	ASTM D7647	>10	<b>0</b>	---	3
Particles >71µm	ASTM D7647	>3	<b>0</b>	---	0
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>16/14/10</b>	---	17/15/12

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.40</b>	---	0.38




# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	34.6	34.0	34.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0763507 **Received** : 14 Jul 2023  
**Lab Number** : 05899304 **Diagnosed** : 17 Jul 2023  
**Unique Number** : 10560660 **Diagnostician** : Wes Davis  
**Test Package** : MOB 2

**AES USA - NORTH CHARLESTON**  
 5400 INTERNATIONAL BLVD, BLDG 88-20  
 NORTH CHARLESTON, SC  
 US 29418  
 Contact: Vanessa Macias  
 vanessa.macias@aes-gse.com  
 T:  
 F: x:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)