

PROBLEM SUMMARY

Sample Rating Trend




KAESER 8146635

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	ABNORMAL	ATTENTION				
Particles >6µm	ASTM D7647	>1300	A 7837	<u>▲</u> 16043	<u>▲</u> 1341				
Particles >14μm	ASTM D7647	>80	197	△ 354	50				
Particles >21µm	ASTM D7647	>20	45	4 3	6				
Particles >38μm	ASTM D7647	>4	<u>^</u> 7	1	1				
Oil Cleanliness	ISO 4406 (c)	>/17/13	22/20/15	<u>\$\lambda\$\$ 23/21/16</u>	2 0/18/13				

Customer Id: HOWGRO Sample No.: KC100950 Lab Number: 05899326 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

27 Mar 2023 Diag: Jonathan Hester

ISO



We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



22 Dec 2022 Diag: Jonathan Hester

150



No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



16 Sep 2022 Diag: Don Baldridge

ISO




Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 8146635

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Mar2022	Jun2022 Sep2022	Dec2022 Mar2023	Jun 2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC100950	KC106452	KC106444
Sample Date		Client Info		15 Jun 2023	27 Mar 2023	22 Dec 2022
Machine Age	hrs	Client Info		7232	6185	5145
Oil Age	hrs	Client Info		3109	2062	1025
Oil Changed		Client Info		Not Changd	Not Changd	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	<1	4
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	4	10	8
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	<1	0	18
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		4	2	1
Zinc	ppm	ASTM D5185m		0	18	48
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	0
Sodium	ppm	ASTM D5185m		<1	<1	9
Potassium	ppm	ASTM D5185m	>20	0	0	7
Water	%	ASTM D6304	>0.05	0.005	0.008	0.016
ppm Water	ppm	ASTM D6304	>500	59.7	84.3	167.7
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		34796	55191	5534
Particles >6µm		ASTM D7647	>1300	A 7837	<u>▲</u> 16043	<u>▲</u> 1341
Particles >14µm		ASTM D7647	>80	<u> </u>	△ 354	50
Particles >21µm		ASTM D7647	>20	45	▲ 43	6
Particles >38μm		ASTM D7647	>4	<u>^</u> 7	1	1
Particles >71µm		ASTM D7647	>3	2	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>22/20/15</u>	<u>△</u> 23/21/16	2 0/18/13
FLUID DEGRADA	NOITA	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.45	0.39	0.36



OIL ANALYSIS REPORT





Lab Number **Unique Number**

+05899326

: 10560682 : IND 2

Diagnosed

Diagnostician : Don Baldridge

Test Package Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

US 34736

T: F:

Contact: Service Manager