


PROBLEM SUMMARY

Machine Id KAESER CSD75T 7423930 (S/N 1087) Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status		ABNORMAL	NORMAL	NORMAL			
Particles >6µm	ASTM D7647 >130	0 🔺 6593	563	911			
Particles >14µm	ASTM D7647 >80	🔺 162	43	38			
Particles >21µm	ASTM D7647 >20	<u> </u>	8	10			
Oil Cleanliness	ISO 4406 (c) >/17	7/13 🔺 22/20/15	16/13	17/12			


Customer Id: PANCUMGA Sample No.: KCP53567 Lab Number: 05899332 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 ihester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

28 Feb 2022 Diag: Don Baldridge





Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



04 Jun 2021 Diag: Don Baldridge



Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



ISO

12 Nov 2020 Diag: Jonathan Hester

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT



Compressor Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.




SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP53567	KC96700	KC99977
Sample Date		Client Info		15 Jun 2023	28 Feb 2022	04 Jun 2021
Machine Age	hrs	Client Info		4752	3294	1987
Oil Age	hrs	Client Info		8000	1300	1987
Oil Changed		Client Info		Not Changd	Changed	Not Changd
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	<1
Aluminum		ASTM D5185m	>10	۰ <1	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	<1
	ppm		>10	5	4	
Copper	ppm					<1
Tin	ppm	ASTM D5185m	>10	0	<1	<1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	<1	11
Barium	ppm	ASTM D5185m	90	0	0	16
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m	90	36	48	78
Calcium	ppm	ASTM D5185m	2	0	0	2
Phosphorus	ppm	ASTM D5185m		4	3	2
Zinc	ppm	ASTM D5185m		10	5	0
Sulfur	ppm	ASTM D5185m		21426	16530	17092
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		8	16	15
Potassium	ppm	ASTM D5185m	>20	7	11	4
Water	%	ASTM D6304	>0.05	0.024	0.018	0.040
ppm Water	ppm	ASTM D6304		246.9	185.0	402.4
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		27934	2645	2714
Particles >6µm		ASTM D7647	>1300	<u> </u>	563	911
Particles >14µm		ASTM D7647		A 162	43	38
Particles >21µm		ASTM D7647		<u>^</u> 28	8	10
Particles >38µm		ASTM D7647	>4	0	1	0
Particles >71µm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 22/20/15	16/13	17/12
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.36	0.32	0.380


Acid Number (AN) Report Id: PANCUMGA [WUSCAR] 05899332 (Generated: 07/18/2023 17:44:06) Rev: 1


Contact/Location: Service Manager - PANCUMGA



OIL ANALYSIS REPORT








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPER	TIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.4	44.2	44.1
SAMPLE IMAGE	S	method	limit/base	current	history1	history2
Color						



Bottom



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - PANCUMGA