

### **PROBLEM SUMMARY**

Sample Rating Trend

ISO


## Formulation-FHG

Sew Euro Drive FHG56LB01 Standardization Tank, Agitator

Gearbox

JAX FGG-AW ISO 220 (--- GAL)

### COMPONENT CONDITION SUMMARY



### RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS										
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL					
Particles >4µm	ASTM D7647	>20000	<b>4</b> 90406							
Particles >6µm	ASTM D7647	>5000	<b>6019</b>							
Oil Cleanliness	ISO 4406 (c)	>21/19/16	<b>4</b> 24/20/13							

Customer Id: NOVFRANC Sample No.: WC0808219 Lab Number: 05899917 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### HISTORICAL DIAGNOSIS

### 20 Jun 2023 Diag: Jonathan Hester

WATER



We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. There is a moderate amount of visible silt present in the sample. Sample is layered with different type/density oil. The AN level is acceptable for this fluid.



### 09 Jun 2022 Diag: Don Baldridge

VIS DEBRIS



We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 29 Jun 2021 Diag: Jonathan Hester

ISO



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






### **OIL ANALYSIS REPORT**

# Formulation-FHG

## Sew Euro Drive FHG56LB01 Standardization Tank, Agitator

Gearbox

JAX FGG-AW ISO 220 (--- GAL)





### **DIAGNOSIS**

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jan2020	Jul2020 Dec2020	Jun2021 Jun2022 Jun2023	Jul2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0808219	WC0782839	WC0706856
Sample Date		Client Info		13 Jul 2023	20 Jun 2023	09 Jun 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	8	45	17
Chromium	ppm	ASTM D5185m	>15	0	<1	<1
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	1	2
Lead	ppm	ASTM D5185m	>100	0	0	<1
Copper	ppm	ASTM D5185m		0	0	<1
Tin	ppm	ASTM D5185m	>25	0	0	<1
Antimony	ppm	ASTM D5185m				
Vanadium		ASTM D5185m	20	0	0	0
	ppm			0	0	
Cadmium	ppm	ASTM D5185m		U	U	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<1	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		1	8	3
Phosphorus	ppm	ASTM D5185m		688	434	452
Zinc	ppm	ASTM D5185m		0	0	3
Sulfur	ppm	ASTM D5185m		709	415	435
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	2	8	5
Sodium	ppm	ASTM D5185m		0	2	2
Potassium	ppm	ASTM D5185m	>20	<1	0	<1
Water	%	ASTM D6304	>0.2	0.007	0.008	0.014
ppm Water	ppm	ASTM D6304	>2000	73.7	81.0	140.7
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	<b>90406</b>		
Particles >6µm		ASTM D7647	>5000	<b>6019</b>		
Particles >14µm		ASTM D7647	>640	44		
Particles >21µm		ASTM D7647	>160	10		
Particles >38µm		ASTM D7647	>40	0		
Particles >71µm		ASTM D7647	>10	0		
Oil Cleanliness		ISO 4406 (c)	>21/19/16	△ 24/20/13		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
			mm/base			
Acid Number (AN)	mg KOH/g	ASTM D8045		0.76	0.63	0.61



### OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number** 

: WC0808219 : 05899917

Received Diagnosed : 10561273

: 18 Jul 2023 Diagnostician : Don Baldridge

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

FRANKLINTON, NC US 27525

Contact: BRUCE THOMAS brct@novozymes.com

T: (919)494-3146 F: (919)494-3456