


OIL ANALYSIS REPORT

Sample Rating Trend





VILTER Component Refrigeration Compressor Fluid USPI 1009-68 SC (--- LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

May2020 0x20120 Feb.2021 Jun2021 Αωρ2021 Dec2021 Μαγ2022 Αωρ2022 Αωρ2022 Δου2023						
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP248959	USP245614	USP235777
Sample Date		Client Info		12 Jul 2023	13 Apr 2023	24 Aug 2022
Machine Age	hrs	Client Info		28301	26711	2207
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	<1	0	0
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m		0	0	0
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m		0	<1	0
Tin	ppm	ASTM D5185m	>4	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	<1
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		<1	0	1
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m	50	27	26	17
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	0	0	0
Sodium	ppm	ASTM D5185m		0	<1	0
Potassium	ppm	ASTM D5185m		0	0	0
Water	%	ASTM D6304	>0.01	0.001	0.001	0.003
ppm Water	ppm	ASTM D6304	>100	4.0	14.2	26.4
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	1720	643	419
Particles >6μm		ASTM D7647	>2500	356	92	34
Particles >14μm		ASTM D7647	>320	30	10	3
Particles >21µm		ASTM D7647	>80	9	4	1
Particles >38μm		ASTM D7647	>20	0	0	0
Particles >71μm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	18/16/12	17/14/10	16/12/9
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.013	0.014	0.014



OIL ANALYSIS REPORT





Certificate L2367

Lab Number **Unique Number**

: 05899935 : 10561291 Test Package : IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: 18 Jul 2023 Diagnosed Diagnostician : Doug Bogart DAKOTA CITY, NE US

Contact:

F:

doug.bogart@wearcheck.com

T:

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)