


PROBLEM SUMMARY

BUSCH VAC PUMP 9 (S/N 5596438)

Pump Fluid USPI VAC 100 (--- GAL)

COMPONENT CONDITION SUMMARY



No relevant graphs to display

RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS								
Sample Status				ABNORMAL	NORMAL	ABNORMAL		
Silt	scalar	*Visual	NONE	🔺 MODER	NONE	NONE		

Customer Id: SIOSIOIOW Sample No.: USP255075 Lab Number: 05899949 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>

RECOMMENDED A	RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description			
Change Filter			?	We recommend you service the filters on this component.			
Alert			?	We were unable to perform a particle count due to a high concentration of particles present in this sample.			

HISTORICAL DIAGNOSIS



22 Mar 2023 Diag: Doug Bogart

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report

11 Dec 2022 Diag: Jonathan Hester



We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.All component wear rates are normal. There is a high amount of particulates present in the oil. Free water present. The AN level is acceptable for this fluid.

05 Sep 2022 Diag: Doug Bogart





Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







OIL ANALYSIS REPORT

BUSCH VAC PUMP 9 (S/N 5596438)

Pump Fluid USPI VAC 100 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear


All component wear rates are normal.

Contamination

There is a moderate amount of visible silt present in the sample.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP255075	USPM27662	USPM25172
Sample Date		Client Info		16 Jul 2023	22 Mar 2023	11 Dec 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	18	<1	<1
Chromium	ppm	ASTM D5185m		0	0	0
Nickel	ppm	ASTM D5185m	>5	0	<1	<1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m		0	<1	<1
Lead	ppm	ASTM D5185m		0	0	0
Copper	ppm	ASTM D5185m		1	0	<1
Tin	ppm	ASTM D5185m		0	<1	0
Vanadium	ppm	ASTM D5185m	~5	0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES	I - I -	method	limit/base	current	history1	history2
Boron	ppm		0	0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m	0	0	0	0
Magnesium	ppm	ASTM D5185m	0	0	1	0
Calcium	ppm	ASTM D5185m		0	0	0
		ASTM D5185m	1800	436	313	429
Phosphorus Zinc	ppm	ASTM D5185m	0	430	6	429
Sulfur	ppm	ASTM D5185m	0	1233	820	1032
	ppm		-			
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	3	5	7
Sodium	ppm	ASTM D5185m		0	<1	0
Potassium	ppm	ASTM D5185m	>20	0	<1	0
Water	%	ASTM D6304		0.011	0.007	0.054
ppm Water	ppm	ASTM D6304	>.1	112.4	76.0	540
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000		588	▲ 200553
Particles >6µm		ASTM D7647			144	<mark>▲</mark> 79837
Particles >14µm		ASTM D7647	>160		19	A 281
Particles >21µm		ASTM D7647	>40		5	13
Particles >38µm		ASTM D7647	>10		1	1
Particles >71µm		ASTM D7647	>3		0	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14		16/14/11	A 25/23/15
		(-)				
FLUID DEGRAD	ATION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT









VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	A MODER	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual		NEG	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG	2 .0
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	91	93.1	93.6	83.6
SAMPLE IMAGES		method	limit/base	current	history1	history2

Color



Bottom



Contact/Location: Service Manager - SIOSIOIOW