

# **OIL ANALYSIS REPORT**

### Sample Rating Trend



COMPRESSOR 3 (S/N 81528

**Air Compressor** 

USPI MAX FG AIR 46 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

76010\									
376010)									
-									
			ė						
	May	2021 Jun2021	Dec2021	May2022	Oct2022	Jan 2023	Apr2023	Jul2023	
	moya	2021 00112021	0002021	May2022	OCIZOZZ	UMIZUZJ	Apizozo	0012023	
SAMPLE INFORMATION									
ample Number	Client Ir	nfo		ι	JSPM	290 <sup>-</sup>	12	USP	M
ample Date	Client Ir	nfo		1	0 Jul	202	3	04 A	pı
•									

Sample Number		Client Info		USPM29012	USPM24894	USPM25384
Sample Date		Client Info		10 Jul 2023	04 Apr 2023	10 Jan 2023
Machine Age	hrs	Client Info		23330	22758	22230
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>70	0	0	0
Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>6	0	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>20	0	0	0
Copper	ppm	ASTM D5185m	>80	0	0	0
Tin	ppm	ASTM D5185m	>15	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	1	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	0	0	0	0
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	2	2	1
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	0	0	2	0
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>12	0	<1	0
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Water	%	ASTM D6304	>0.1	0.008	0.007	0.006
ppm Water	ppm	ASTM D6304	>1000	89.4	72.8	64.3
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	139	113	1670
Particles >6µm		ASTM D7647	>2500	82	46	320
Particles >14μm		ASTM D7647	>640	27	7	32
Particles >21μm		ASTM D7647	>160	10	2	11
Particles >38μm		ASTM D7647	>40	1	0	0
Particles >71μm		ASTM D7647	>10	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/16	14/14/12	14/13/10	18/15/12
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.16	0.25	0.17	0.26



## **OIL ANALYSIS REPORT**







Certificate L2367

Sample No. Lab Number **Unique Number** 

Test Package

: USPM29012 : 05899962 : 10561318 : IND 2

Received Diagnosed

: 18 Jul 2023 Diagnostician : Doug Bogart

431 W 16TH ST HOLLAND, MI US 49423

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: