




OIL ANALYSIS REPORT



Machine Id
MTNM01BE
Component
Biogas Engine
Fluid
SHELL SHELL MYSELLA S3 N 40 (--- GAL)

Sample Rating Trend



DIRT



DIAGNOSIS

▲ Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

Elemental level of silicon (Si) above normal.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0775122	WC0770239	WC0770237
Sample Date	Client Info		13 Jul 2023	01 May 2023	28 Apr 2023
Machine Age	hrs	Client Info	38435	38269	38200
Oil Age	hrs	Client Info	557	391	322
Oil Changed	Client Info		Not Chngd	Changed	Changed
Sample Status			ABNORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >15	13	4	2
Chromium	ppm	ASTM D5185m >4	<1	0	0
Nickel	ppm	ASTM D5185m >2	<1	0	0
Titanium	ppm	ASTM D5185m	<1	0	0
Silver	ppm	ASTM D5185m >5	0	0	0
Aluminum	ppm	ASTM D5185m >6	4	0	2
Lead	ppm	ASTM D5185m >9	0	0	0
Copper	ppm	ASTM D5185m >6	2	1	<1
Tin	ppm	ASTM D5185m >4	4	2	1
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	2	1	2
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	2	2	2
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	14	13	13
Calcium	ppm	ASTM D5185m	1774	1603	1695
Phosphorus	ppm	ASTM D5185m	360	325	348
Zinc	ppm	ASTM D5185m	448	431	430
Sulfur	ppm	ASTM D5185m	4133	3476	3598

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >181	▲ 191	145	160
Sodium	ppm	ASTM D5185m	0	0	<1
Potassium	ppm	ASTM D5185m >20	0	1	0

INFRA-RED





	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	0.1	0.1	0.1
Nitration	Abs/cm	*ASTM D7624 >20	5.6	4.7	4.8
Sulfation	Abs/.1mm	*ASTM D7415 >30	23.4	19.8	20.1

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	16.3	14.3	14.5
Acid Number (AN)	mg KOH/g	ASTM D8045	1.15	1.06	1.36
Base Number (BN)	mg KOH/g	ASTM D2896 5	3.97	3.46	3.34











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.5	13.8	13.6

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC0775122 Received : 17 Jul 2023
 Lab Number : 05900132 Diagnosed : 21 Jul 2023
 Unique Number : 10561488 Diagnostician : Jonathan Hester
 Test Package : MOB 2

EDL NA Recips-Morgantown
 Morgantown Powerstation, 950 Shiloh
 Morgantown, PA
 US 19543
 Contact: ARON GUNN
 aron.gunn@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: