




# OIL ANALYSIS REPORT

Sample Rating Trend



**DIRT**



Machine Id  
**Coopersville CAT 1 CPVM01BE**  
 Component  
**Biogas Engine**  
 Fluid  
**CHEVRON HDAX 6500 LFG GAS ENGINE OIL (--- GAL)**

## DIAGNOSIS

### Recommendation

We recommend that you drain the oil and perform a filter service on this component if not already done. We recommend an early resample to monitor this condition.

### Wear

The tin level is abnormal.

### Contamination

Elemental level of silicon (Si) above normal.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0819399</b>	WC0819403	WC0819393
Sample Date	Client Info		<b>13 Jul 2023</b>	30 Jun 2023	21 Jun 2023
Machine Age	hrs	Client Info	<b>10866</b>	10648	10436
Oil Age	hrs	Client Info	<b>858</b>	640	428
Oil Changed	Client Info		<b>Not Chngd</b>	Not Chngd	Not Chngd
Sample Status			<b>SEVERE</b>	NORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>15	<b>10</b>	6	7
Chromium	ppm	ASTM D5185m	>4	<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185m	>2	<b>&lt;1</b>	<1	<1
Titanium	ppm	ASTM D5185m		<b>0</b>	<1	0
Silver	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>6	<b>3</b>	2	<1
Lead	ppm	ASTM D5185m	>9	<b>3</b>	0	1
Copper	ppm	ASTM D5185m	>14	<b>6</b>	4	4
Tin	ppm	ASTM D5185m	>4	<b>12</b>	7	6
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		<b>4</b>	4	5
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>2</b>	2	2
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>35</b>	34	30
Calcium	ppm	ASTM D5185m		<b>1961</b>	1647	1772
Phosphorus	ppm	ASTM D5185m		<b>298</b>	262	277
Zinc	ppm	ASTM D5185m		<b>375</b>	326	346
Sulfur	ppm	ASTM D5185m		<b>2242</b>	1874	1966

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>181	<b>229</b>	146	123
Sodium	ppm	ASTM D5185m		<b>0</b>	<1	0
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	0	2

## INFRA-RED

	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		<b>0.1</b>	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	<b>6.8</b>	6.2	5.8
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>19.1</b>	18.1	17.3


## FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>13.8</b>	13.0	11.7
Acid Number (AN)	mg KOH/g	ASTM D8045	1.2	<b>1.22</b>	0.943	0.62
Base Number (BN)	mg KOH/g	ASTM D2896	4.5	<b>3.23</b>	5.02	5.24




# OIL ANALYSIS REPORT

## Non-ferrous Metals



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


## Acid Number




FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.7	13.6	13.4

## GRAPHS


## Acid Number




## Iron (ppm)




## Lead (ppm)




## Aluminum (ppm)




## Chromium (ppm)




## Base Number




## Copper (ppm)




## Silicon (ppm)




## Viscosity @ 100°C



## Viscosity @ 100°C



## Base Number



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0819399 **Received** : 17 Jul 2023  
**Lab Number** : 05900137 **Diagnosed** : 19 Jul 2023  
**Unique Number** : 10561493 **Diagnostician** : Don Baldrige  
**Test Package** : MOB 2

**EDL NA Recips-Coopersville**  
 Coopersville Powerstation, 15362 68th Avenue  
 Coopersville, MI  
 US 49404  
 Contact: Daniel Young  
 daniel.young@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: