




OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area
SECURITY HOUSTON TEXAS
Machine Id
JENBACHER SC-U2
Component
Biogas Engine
Fluid
MOBIL PEGASUS 805 (250 GAL)

DIAGNOSIS

Recommendation

We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

Wear

An increase in the iron level is noted. Cylinder, crank, or cam shaft wear is indicated.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0427968	WC0427970	WCM2313154
Sample Date	Client Info		13 Jul 2023	05 Jul 2023	30 Apr 2020
Machine Age	hrs	Client Info	61215	61035	59973
Oil Age	hrs	Client Info	1231	855	735
Oil Changed	Client Info		Not Chngd	Not Chngd	N/A
Sample Status			SEVERE	SEVERE	ABNORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	102	129	25
Chromium	ppm	ASTM D5185m >5	2	2	2
Nickel	ppm	ASTM D5185m >2	0	<1	<1
Titanium	ppm	ASTM D5185m	0	0	<1
Silver	ppm	ASTM D5185m >5	0	0	0
Aluminum	ppm	ASTM D5185m >15	4	4	4
Lead	ppm	ASTM D5185m >20	<1	<1	0
Copper	ppm	ASTM D5185m >15	1	1	<1
Tin	ppm	ASTM D5185m >5	1	1	<1
Antimony	ppm	ASTM D5185m	---	---	16
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 80	0	0	<1
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	<1	<1	0
Manganese	ppm	ASTM D5185m	1	1	<1
Magnesium	ppm	ASTM D5185m	6	11	2
Calcium	ppm	ASTM D5185m 1020	1584	1517	1598
Phosphorus	ppm	ASTM D5185m 220	321	325	303
Zinc	ppm	ASTM D5185m 230	370	370	344
Sulfur	ppm	ASTM D5185m 1000	3634	3721	2394

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >150	107	101	161
Sodium	ppm	ASTM D5185m >20	<1	2	1
Potassium	ppm	ASTM D5185m >20	<1	2	2

INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844 >2	0.1	0.1	0.1
Nitration	Abs/cm	*ASTM D7624 >20	5.6	5.5	6.3
Sulfation	Abs/.1mm	*ASTM D7415 >30	20.7	20.6	20.3


FLUID DEGRADATION

	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	13.5	13.2	14.5
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	0.84	0.83	1.176
Base Number (BN)	mg KOH/g	ASTM D2896 6.2	1.91	5.39	3.52




OIL ANALYSIS REPORT


Ferrous Alloys




Acid Number



Base Number



Viscosity @ 100°C




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG


FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.5	13.6	14.2

GRAPHS


Iron (ppm)




Aluminum (ppm)




Copper (ppm)




Viscosity @ 100°C




Lead (ppm)




Chromium (ppm)



Silicon (ppm)



Base Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0427968 **Received** : 17 Jul 2023
Lab Number : 05900153 **Diagnosed** : 20 Jul 2023
Unique Number : 10561509 **Diagnostician** : Angela Borella
Test Package : MOB 2

MONTAUK ENERGY CAPITAL LLC (TEXAS) LP
 1412 N SAM HOUSTON PKWY E, SUITE 100
 HOUSTON, TX
 US 77032
 Contact: DAMON MCCLENAN
 dmcclenan@montaukenergy.com
 T: (713)781-1126
 F: (713)781-1127

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)