




OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Machine Id
JOY 5 EPS

Component
Reciprocating Compressor

Fluid
ROYAL PURPLE SYNFILM 100 (100 LTR)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			RP0032913	RP0021815	---
Sample Date	Client Info			24 May 2023	16 Jun 2022	---
Machine Age	hrs	Client Info		0	0	---
Oil Age	hrs	Client Info		15350	12704	---
Oil Changed	Client Info			Not Changed	Not Changed	---
Sample Status				NORMAL	NORMAL	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	12	10	---
Chromium	ppm	ASTM D5185m	>10	0	0	---
Nickel	ppm	ASTM D5185m		1	0	---
Titanium	ppm	ASTM D5185m		0	0	---
Silver	ppm	ASTM D5185m		0	0	---
Aluminum	ppm	ASTM D5185m	>25	1	<1	---
Lead	ppm	ASTM D5185m	>25	23	17	---
Copper	ppm	ASTM D5185m	>50	25	13	---
Tin	ppm	ASTM D5185m	>15	1	1	---
Vanadium	ppm	ASTM D5185m		0	0	---
Cadmium	ppm	ASTM D5185m		<1	<1	---

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	---
Barium	ppm	ASTM D5185m		0	0	---
Molybdenum	ppm	ASTM D5185m		0	0	---
Manganese	ppm	ASTM D5185m		<1	<1	---
Magnesium	ppm	ASTM D5185m	90	58	72	---
Calcium	ppm	ASTM D5185m		2	2	---
Phosphorus	ppm	ASTM D5185m		41	32	---
Zinc	ppm	ASTM D5185m		9	4	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	1	---
Sodium	ppm	ASTM D5185m		10	11	---
Potassium	ppm	ASTM D5185m	>20	<1	2	---
Water	%	ASTM D6304	>0.1	0.003	0.011	---
ppm Water	ppm	ASTM D6304	>1000	38.6	113.4	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.25	0.30	0.33	---

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	NONE	---
Debris	scalar	*Visual	NONE	LIGHT	LIGHT	---
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	---
Free Water	scalar	*Visual		NEG	NEG	---

OIL ANALYSIS REPORT







FLUID PROPERTIES method limit/base current history1 history2

Visc @ 40°C cSt ASTM D445 100 **107** 103 ---

SAMPLE IMAGES method limit/base current history1 history2



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0032913 **Received** : 17 Jul 2023
Lab Number : **05900756** **Diagnosed** : 19 Jul 2023
Unique Number : 10562112 **Diagnostician** : Angela Borella
Test Package : IND 2

PAESA
 CHAPULTEPEE 304-A COL. REGINA
 MONTERREY,
 NL
 Contact: MARCELA TOVAR
 marcelatovar@grupoati.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: