

COOLANT REPORT

Sample Rating Trend NORMAL

Gen Tech USA GEN 1

Component

Coolant

CONVENTIONAL COOLANT (--- GAL)

Recommendation

The fluid is suitable for further service.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0802635	WC0700364	
Sample Date		Client Info		14 Jul 2023	24 May 2022	
Machine Age	hrs	Client Info		386	360	
Oil Age	hrs	Client Info		0	360	
Oil Changed		Client Info		Changed	N/A	
Sample Status				NORMAL	NORMAL	
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		1.068	1.070	
рН	Scale 0-14	ASTM D1287		8.91	9.97	
Nitrites	ppm	AP-053:2009		412	1200	
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		50.6	52.6	
Freezing Point	°F	ASTM D3321		-35	-40	
Total Dissolved Solids				220.0	283.5	
Carboxylate				n/a	n/a	
VISUAL		method	limit/base	current	history1	history2
Coolant Color		*Visual		Yllow	Pink	
Coolant Appearance		*Visual	Clear	normal	normal	
Color						no image
Bottom						no image



COOLANT REPORT





Laboratory Sample No. Lab Number **Unique Number**

: 10562254

: WC0802635 : 05900898

Received

: 17 Jul 2023 Diagnosed : 20 Jul 2023 Diagnostician : Jonathan Hester **ALTERNATIVE POWER** 1000 NORTHGATE CT MORRISVILLE, NC US 27560

Test Package : COOL- (Additional Tests: COOL, FT-IR, ICP, KF, KV100, SCREEN Contact: ROBERT MCARTHUR To discuss this sample report, contact Customer Service at 1-800-237-1369.

rmcarthur@bittingelectric.com

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

T: (919)467-9417

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)