


# **COOLANT REPORT**



NORMAL



Machine Id Gen Tech USA Gen 2

Component

**Radiator Coolant** 

**CONVENTIONAL COOLANT (--- GAL)** 

#### Recommendation

The fluid is suitable for further service.

#### Contamination

There is no indication of any contamination in the coolant.


### **Fluid Condition**

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0802636	WC0700362	
Sample Date		Client Info		14 Jul 2023	24 May 2022	
Machine Age	hrs	Client Info		207	177	
Oil Age	hrs	Client Info		207	177	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		1.068	1.068	
pH	Scale 0-14	ASTM D1287		8.84	7.79	
Nitrites	ppm	AP-053:2009		676	936	
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		50.2	50.8	
Freezing Point	°F	ASTM D3321		-35	-35	
Total Dissolved Solids				254.5	482.5	
Carboxylate				n/a	n/a	
VISUAL		method	limit/base	current	history1	history2
Coolant Color		*Visual		Yllow	Yllow	
Coolant Appearance		*Visual	Clear	normal	normal	
Color				Temporal		no image
Bottom						no image



## **COOLANT REPORT**





Laboratory Sample No. Lab Number Unique Number : 10562255

: WC0802636 : 05900899

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Diagnosed

: 17 Jul 2023 : 20 Jul 2023

Diagnostician : Jonathan Hester Test Package : COOL- (Additional Tests: COOL, ICP, KV40, SCREEN)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) **ALTERNATIVE POWER** 1000 NORTHGATE CT MORRISVILLE, NC

US 27560 Contact: ROBERT MCARTHUR

rmcarthur@bittingelectric.com

T: (919)467-9417