

No relevant graphs to display

RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS							
Sample Status				ABNORMAL	NORMAL	NORMAL	
Debris	scalar	*Visual	NONE	🔺 MODER	LIGHT	LIGHT	

Customer Id: CAREMP Sample No.: USP250464 Lab Number: 05901300 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED	O ACTIONS			
Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component.
Alert			?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS



30 Jan 2023 Diag: Doug Bogart

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



28 Sep 2022 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend

VIS DEBRIS

EXTRUDER (S/N 12584-1)

Gearbox Fluid GEAR OIL ISO 150 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Sep	2022	Jan2023 Jul20	123	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP250464	USP05790920	USP219415
Sample Date		Client Info		17 Jul 2023	30 Jan 2023	28 Sep 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	0	0	0
Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		<1	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	<1	0
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>200	1	<1	<1
Tin	ppm	ASTM D5185m	>25	0	0	0
Vanadium	ppm	ASTM D5185m		<1	<1	<1
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	50	0	0	0
Barium	ppm	ASTM D5185m	15	0	0	0
Molybdenum	ppm	ASTM D5185m	15	0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	50	1	<1	0
Calcium	ppm	ASTM D5185m	50	0	<1	0
Phosphorus	ppm	ASTM D5185m	350	410	504	413
Zinc	ppm	ASTM D5185m	100	5	47	17
Sulfur	ppm	ASTM D5185m	12500	1642	655	381
CONTAMINANTS	\$	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	<1	1	1
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Water	%	ASTM D6304	>0.2	0.008	0.003	0.006
ppm Water	ppm	ASTM D6304	>2000	81.9	35.2	63.1
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000		5514	5532
Particles >6µm		ASTM D7647	>5000		776	1689
Particles >14µm		ASTM D7647	>640		43	215
Particles >21µm		ASTM D7647	>160		9	76
Particles >38µm		ASTM D7647	>40		1	5
Particles >71µm		ASTM D7647	>10		0	0
Oil Cleanliness		ISO 4406 (c)	>21/19/16		20/17/13	20/18/15
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.85	0.63	0.46	0.58



OIL ANALYSIS REPORT



Jan 30/23

history1

NONE

NONE

NONE

NONE

LIGHT

NONE

NORML

NORML

NEG

NEG

148

history

history1

history2

NONE

NONE

NONE

NONE

LIGHT

NONE

NORML

NORML

history2

history2

NEG

NEG

144



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

: 10562656

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: IND 2

Diagnostician

: Doug Bogart

Unique Number

Test Package

Certificate L2367

Contact/Location: SHAWN ANDERS - CAREMP