



Built for a lifetime."

COMPRESSORS

KAESER 7522298

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS						
Sample Status			ATTENTION	ABNORMAL		
Particles >14µm	ASTM D7647	>80	<u> </u>			
Particles >21µm	ASTM D7647	>20	<u> </u>			
Oil Cleanliness	ISO 4406 (c)	>/17/13	<u> </u>			

Customer Id: HELLIV Sample No.: KCPA002653 Lab Number: 05901321 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 <u>don.b505@comcast.net</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

28 Jan 2022 Diag: Angela Borella

VIS DEBRIS



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend

ISO

Machine Id **KAESER 7522298** Component

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

A Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				_		
			Jan2022	Jun2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA002653	KC96146	
Sample Date		Client Info		12 Jun 2023	28 Jan 2022	
Machine Age	hrs	Client Info		3539	8679	
Oil Age	hrs	Client Info		0	1910	
Oil Changed		Client Info		N/A	Not Changd	
Sample Status				ATTENTION	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	21	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	1	0	
Lead	ppm	ASTM D5185m	>10	0	2	
Copper	ppm	ASTM D5185m	>50	3	3	
Tin	ppm	ASTM D5185m	>10	0	<1	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	<1	
Barium	ppm	ASTM D5185m	90	0	10	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	90	18	40	
Calcium	ppm	ASTM D5185m	2	0	2	
Phosphorus	ppm	ASTM D5185m		2	0	
Zinc	ppm	ASTM D5185m		0	2	
Sulfur	ppm	ASTM D5185m		21206	16077	
CONTAMINANTS	S	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	4	
Sodium	ppm	ASTM D5185m		4	19	
Potassium	ppm	ASTM D5185m	>20	2	4	
Water	%	ASTM D6304	>0.05	0.008	0.004	
ppm Water	ppm	ASTM D6304	>500	80.2	45.5	
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2055		
Particles >6µm		ASTM D7647	>1300	681		
Particles >14µm		ASTM D7647	>80	A 81		
Particles >21μm		ASTM D7647	>20	<u> </u>		
Particles >38µm		ASTM D7647	>4	1		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.32	0.38	
·24:02) Pov: 1	ing itori/g	7.0 FW D0043	J.T		0.00 tion: Sonvice Ma	

Report Id: HELLIV [WUSCAR] 05901321 (Generated: 07/20/2023 11:24:03) Rev: 1

Contact/Location: Service Manager - HELLIV



OIL ANALYSIS REPORT

ethod limit/base			
sual NONE	LIGHT	NONE	
sual NONE	NONE	NONE	
sual NONE	NONE	NONE	
sual NONE	NONE	NONE	
sual NONE	LIGHT 🤺	MODER	
sual NONE	NONE	NONE	
sual NORML	NORML	NORML	
sual NORML	NORML	NORML	
sual >0.05	NEG	NEG	
sual	NEG	NEG	
ethod limit/base	current	history1	history2
TM D445 46	43.5	44.5	
ethod limit/base	current	history1	history2
			no image
			no image
	Particle Count		110293
491,520	1		T ²⁶
122,880	-		-24
30,720			
50,720			-22
7,680			-20
Jun 12/23 (per 1 ml			19
L 1,920	1. 1		-10
Jun 12/23. 1.070 (ml) 1.070 (ml)			+18
4			
			-14
30	-		-12
		1	-10
Construction of the second sec	Biorevernal	1	T ^{ro}
Jun12/23	-		
L D		1	6
4	^{4μ} 6μ 1 Acid Number	14μ 21μ	38µ 71µ
© ^{0.50}			
(⁶ ,0.50 HOX 0.40	Base		
0.20 mg N P0 10 V P0 0.00			
2 0.10]		
, 0.00			
Jun 12/23	Jan 28/22		
Ave., Cary, NC 27513 : 18 Jul 2023	5	38150 P	HEL LYMOUTH F
: 20 Jul 2023			LIVONIA, N
n : Don Baldridge			US 4815
		Contact: Se	ervice Manag
			٦
	n : Don Baldridge Count) /37-1369. f accreditation.	n : Don Baldridge Count) <i>'37-1369.</i>	n : Don Baldridge Count) Contact: Se 137-1369. f accreditation.

Contact/Location: Service Manager - HELLIV