


# **OIL ANALYSIS REPORT**

Sample Rating Trend



NORMAL



Machine Id

# KAESER DSD 200 4103520 (S/N 1130)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## DIAGNOSIS

# Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


# **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		\ug2016 Ma	2018 Feb2019 Oct20	20 Apr2021 Nov2021 Sep20	722 Jui2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP53651	KCP59150	KCP59210
Sample Date		Client Info		15 Jul 2023	06 Apr 2023	25 Sep 2022
Machine Age	hrs	Client Info		70465	68161	63610
Oil Age	hrs	Client Info		5060	5845	4552
Oil Changed		Client Info		Not Changd	N/A	N/A
Sample Status				NORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	0	0
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	20	10	34
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	90	2	1	0
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		3	1	2
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		19725	18908	17741
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	0
Sodium	ppm	ASTM D5185m		<1	1	0
Potassium	ppm	ASTM D5185m	>20	0	<1	0
Water	%	ASTM D6304	>0.05	0.009	0.004	0.007
ppm Water	ppm	ASTM D6304	>500	94.7	43.0	75.7
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		795	3005	26638
Particles >6µm		ASTM D7647	>1300	157	841	<u></u> 6198
Particles >14µm		ASTM D7647	>80	9	65	<b>4</b> 03
Particles >21µm		ASTM D7647	>20	2	12	<u></u> 102
Particles >38µm		ASTM D7647	>4	0	1	2
Particles >71µm		ASTM D7647	>3	0	0	1
Oil Cleanliness		ISO 4406 (c)	>17/13	14/10	17/13	△ 20/16
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.43	0.44	0.41



# **OIL ANALYSIS REPORT**



Test Package : IND 2 ( Additional Tests: KF, PrtCount )

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Certificate L2367

T: F:

Contact: SERVICE MANAGER