


# PROBLEM SUMMARY


Area  
**REACTOR 1**  
Machine Id  
**A1 AGITATOR (S/N 11537A)**  
Component  
**Gearbox**  
Fluid  
**ROYAL PURPLE SYNFILM GT220 (13 GAL)**

Sample Rating Trend



## COMPONENT CONDITION SUMMARY

Particle Trend



## RECOMMENDATION

The particle concentrations are elevated since the last sample. This could be a consequence of sample process if the sample was collected without the benefit of a fixed sample port. If possible filter the oil using B5=75 or better quality media. If not, Replace the oil, and use extra caution to flush the agitator sump completely and refill using clean handling utensils. Please resample after a month of run time following oil change to validate results.

## PROBLEMATIC TEST RESULTS

Sample Status			SEVERE	ABNORMAL	ABNORMAL
Particles >4µm	ASTM D7647	>20000	162108	145010	198005
Particles >6µm	ASTM D7647	>5000	32686	49960	72180
Oil Cleanliness	ISO 4406 (c)	>21/19/16	25/22/14	24/23/17	25/23/16

Customer Id: HEXHOPAR  
Sample No.: PLS0000750  
Lab Number: 05901827  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

There are no recommended actions for this sample.

## HISTORICAL DIAGNOSIS

### 10 Jun 2023 Diag: Mike Johnson

#### VISUAL METAL



Filter oil if possible using B6=75 filter media or better. No other action required at this time. Resample at next normal interval. Wear particles are elevated from previous samples but still relatively low. Consistently elevated wear particles can be an early sign of machine failure. Contamination is elevated. Filtration can help extend machine life. Fluid health is acceptable for continued use provided that contamination can be brought under control.

view report



### 09 Mar 2023 Diag: Mike Johnson

#### ISO



Filter oil if possible using B6=75 filter media or better. Filtration will greatly extend machine life. Resample at next normal interval. Wear particles are low and steady. Contamination is significantly elevated. Filter if possible to extend machine life. Fluid health indicators are acceptable for continued use provided that contamination can be brought under control.

view report



### 06 Sep 2022 Diag: Mike Johnson

#### ISO




Filter oil if possible using B6=75 Filter media or better. Oil is very dirty. Consider an oil flush and fill if filtration is not possible. Resample at next normal interval. Wear particles are low and steady. Particle count is excessively high. High particulate can cause premature wear leading to eventual part failure. Fluid health is acceptable for continued use providing that the particulate is brought under control.

view report



# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area  
**REACTOR 1**  
Machine Id  
**A1 AGITATOR (S/N 11537A)**  
Component  
**Gearbox**  
Fluid  
**ROYAL PURPLE SYNFILM GT220 (13 GAL)**

## DIAGNOSIS

### Recommendation

The particle concentrations are elevated since the last sample. This could be a consequence of sample process if the sample was collected without the benefit of a fixed sample port. If possible filter the oil using B5=75 or better quality media. If not, Replace the oil, and use extra caution to flush the agitator sump completely and refill using clean handling utensils. Please resample after a month of run time following oil change to validate results.

### Wear

The wear rate is within the historical tren line.

### Contamination

The particle count is severely elevated. It would be useful to filter the oil while the machine is operating using side-stream (kidney-loop) filtration, with elements rated B6=75 or better.

### Fluid Condition

The viscosity is slightly above the `alert` level of +10%. This could be caused by residual ISO 460 used previously. This is not a concern at this time. Other lubricant health parameters (additives, AN value, Ox-Ni-Su) suggest the oil is good for continued use.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>PLS0000750</b>	PLS0000606	PLS0000598
Sample Date	Client Info			<b>13 Jul 2023</b>	10 Jun 2023	09 Mar 2023
Machine Age	mths	Client Info		<b>0</b>	0	6
Oil Age	mths	Client Info		<b>0</b>	0	0
Oil Changed	Client Info			<b>N/A</b>	N/A	N/A
Sample Status				<b>SEVERE</b>	ABNORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		<b>33</b>	38	21
Iron	ppm	ASTM D5185m	>200	<b>27</b>	▲ 56	23
Chromium	ppm	ASTM D5185m	>15	<b>&lt;1</b>	<1	0
Nickel	ppm	ASTM D5185m	>15	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m		<b>0</b>	<1	0
Silver	ppm	ASTM D5185m		<b>0</b>	<1	0
Aluminum	ppm	ASTM D5185m	>25	<b>3</b>	1	2
Lead	ppm	ASTM D5185m	>100	<b>0</b>	0	0
Copper	ppm	ASTM D5185m	>200	<b>0</b>	<1	0
Tin	ppm	ASTM D5185m	>25	<b>0</b>	0	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>0</b>	0	0
Barium	ppm	ASTM D5185m		<b>0</b>	3	0
Molybdenum	ppm	ASTM D5185m		<b>0</b>	0	0
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m	90	<b>81</b>	132	80
Calcium	ppm	ASTM D5185m		<b>2</b>	4	0
Phosphorus	ppm	ASTM D5185m		<b>4</b>	4	1
Zinc	ppm	ASTM D5185m		<b>&lt;1</b>	2	0
Sulfur	ppm	ASTM D5185m		<b>21506</b>	28292	20326

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	<b>4</b>	8	4
Sodium	ppm	ASTM D5185m		<b>0</b>	1	2
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	<1	0

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		<b>0</b>	0.1	0.1
Nitration	Abs/cm	*ASTM D7624		<b>2.8</b>	2.9	3.0
Sulfation	Abs/.1mm	*ASTM D7415		<b>30.8</b>	31.0	30.4

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	● <b>162108</b>	▲ 145010	▲ 198005
Particles >6µm		ASTM D7647	>5000	▲ <b>32686</b>	▲ 49960	▲ 72180
Particles >14µm		ASTM D7647	>640	<b>141</b>	▲ 1074	601
Particles >21µm		ASTM D7647	>160	<b>11</b>	155	70
Particles >38µm		ASTM D7647	>40	<b>2</b>	12	1
Particles >71µm		ASTM D7647	>10	<b>2</b>	1	0
Oil Cleanliness		ISO 4406 (c)	>21/19/16	● <b>25/22/14</b>	▲ 24/23/17	▲ 25/23/16

# OIL ANALYSIS REPORT




FLUID DEGRADATION	method	limit/base	current	history1	history2
Oxidation	Abs./1mm	*ASTM D7414	<b>26.5</b>	27.1	25.7
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.42</b>	0.42	0.48





VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	▲ LIGHT	VLITE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	<b>249</b>	249	241

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : PLS0000750 **Received** : 18 Jul 2023  
**Lab Number** : 05901827 **Diagnosed** : 23 Aug 2023  
**Unique Number** : 10563183 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2 ( Additional Tests: FT-IR, PQ, PrtCount )

**HEXION - HOPE PLANT**  
 185 N INDUSTRIAL DR  
 HOPE, AR  
 US 71801  
 Contact: JOSEPH MURPHY  
 joseph.murphy@hexion.com;mike.johnson@amrri.com  
 T: (870)722-7305  
 F: (870)722-5678