PROBLEM SUMMARY

Sample Rating Trend



WATER

Machine Id
VP-13 (S/N C-4236)
Component
Pump
Fluid
USPI VAC 100 (--- GAL)

COMPONENT CONDITION SUMMARY





RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status				**ATTENTION**	ATTENTION	NORMAL
Water	%	ASTM D6304		▲ **0.120**	0.024	0.032
ppm Water	ppm	ASTM D6304	>.1	▲ **1201.8**	240.6	322.8
Particles >6µm		ASTM D7647	>1300	▲ **1371**	▲ 1679	506
Oil Cleanliness		ISO 4406 (c)	>19/17/14	▲ **19/18/14**	▲ 20/18/14	18/16/12

Customer Id: JBSBRO
Sample No.: USPM27079
Lab Number: 05901868
Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:
Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

28 Feb 2023 Diag: Doug Bogart

ISO

Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

---

15 Nov 2022 Diag: Doug Bogart

NORMAL

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

---

21 Jul 2022 Diag: Jonathan Hester

NORMAL

Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report

OIL ANALYSIS REPORT

Sample Rating Trend



WATER

Machine Id
VP-13 (S/N C-4236)
Component
Pump
Fluid
USPI VAC 100 (--- GAL)

DIAGNOSIS

Recommendation
Resample at the next service interval to monitor.

Wear
All component wear rates are normal.

Contamination
There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. There is a light concentration of water present in the oil.

Fluid Condition
The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**USPM27079**	USPM26762	USPM24865
Sample Date		Client Info		**17 Jul 2023**	28 Feb 2023	15 Nov 2022
Machine Age	hrs	Client Info		**0**	0	0
Oil Age	hrs	Client Info		**0**	0	0
Oil Changed		Client Info		**N/A**	N/A	N/A
Sample Status				**ATTENTION**	ATTENTION	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	**0**	5	0
Chromium	ppm	ASTM D5185m	>5	**0**	0	0
Nickel	ppm	ASTM D5185m	>5	**0**	0	0
Titanium	ppm	ASTM D5185m	>3	**0**	0	0
Silver	ppm	ASTM D5185m	>3	**0**	0	0
Aluminum	ppm	ASTM D5185m	>7	**3**	2	0
Lead	ppm	ASTM D5185m	>12	**0**	0	0
Copper	ppm	ASTM D5185m	>30	**0**	0	0
Tin	ppm	ASTM D5185m	>9	**0**	<1	<1
Vanadium	ppm	ASTM D5185m		**0**	0	0
Cadmium	ppm	ASTM D5185m		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	**0**	0	0
Barium	ppm	ASTM D5185m	0	**0**	0	0
Molybdenum	ppm	ASTM D5185m	0	**0**	0	0
Manganese	ppm	ASTM D5185m		**0**	0	0
Magnesium	ppm	ASTM D5185m	0	**0**	0	0
Calcium	ppm	ASTM D5185m	0	**0**	4	0
Phosphorus	ppm	ASTM D5185m	1800	**890**	761	910
Zinc	ppm	ASTM D5185m	0	**0**	7	0
Sulfur	ppm	ASTM D5185m	0	**0**	38	14

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	**1**	4	2
Sodium	ppm	ASTM D5185m		**0**	2	0
Potassium	ppm	ASTM D5185m	>20	**<1**	0	0
Water	%	ASTM D6304		▲ **0.120**	0.024	0.032
ppm Water	ppm	ASTM D6304	>.1	▲ **1201.8**	240.6	322.8

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	**3764**	▲ 5552	2130
Particles >6µm		ASTM D7647	>1300	▲ **1371**	▲ 1679	506
Particles >14µm		ASTM D7647	>160	**130**	88	39
Particles >21µm		ASTM D7647	>40	**23**	10	5
Particles >38µm		ASTM D7647	>10	**0**	0	0
Particles >71µm		ASTM D7647	>3	**0**	0	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	▲ **19/18/14**	▲ 20/18/14	18/16/12

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.05	**0.085**	0.21	0.17

OIL ANALYSIS REPORT

Particle Trend



Water



Water



Acid Number



Viscosity @ 40°C



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**LIGHT**	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual		**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	91	**97.0**	102	98.0

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS

Ferrous Alloys



Non-ferrous Metals



Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : USPM27079
Lab Number : 05901868
Unique Number : 10563224
Test Package : IND 2

Received : 18 Jul 2023
Diagnosed : 19 Jul 2023
Diagnostician : Doug Bogart

JBS FOODS

BROOKS, AB
CA T1R 1C6
Contact:

T:
F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)