




OIL ANALYSIS REPORT

Sample Rating Trend



DEGRADATION



Machine Id
3191 - PLOGER
 Component
Transmission (Manual)
 Fluid
NOT GIVEN (--- GAL)

DIAGNOSIS

▲ Recommendation

We recommend that you drain the fluid from the component if this has not already been done. We recommend an early resample to monitor this condition.

▲ Wear

The aluminum level is abnormal. The copper level is abnormal.

▲ Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the fluid.

▲ Fluid Condition

The AN level is at the top-end of the recommended limit.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0828728	WC0712574	WC0588416
Sample Date	Client Info		14 Jun 2023	20 May 2022	15 May 2021
Machine Age	mls	Client Info	376225	312537	233419
Oil Age	mls	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>200	120	115	94
Chromium	ppm	ASTM D5185m	>5	2	2	2
Nickel	ppm	ASTM D5185m	>5	1	<1	1
Titanium	ppm	ASTM D5185m		<1	<1	<1
Silver	ppm	ASTM D5185m	>7	0	0	<1
Aluminum	ppm	ASTM D5185m	>25	▲ 66	37	26
Lead	ppm	ASTM D5185m	>45	<1	<1	<1
Copper	ppm	ASTM D5185m	>225	▲ 261	▲ 248	193
Tin	ppm	ASTM D5185m	>10	<1	<1	<1
Antimony	ppm	ASTM D5185m		---	---	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		226	162	295
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		2	6	2
Manganese	ppm	ASTM D5185m		26	23	23
Magnesium	ppm	ASTM D5185m		2	<1	1
Calcium	ppm	ASTM D5185m		169	165	169
Phosphorus	ppm	ASTM D5185m		1266	1350	1257
Zinc	ppm	ASTM D5185m		41	31	12
Sulfur	ppm	ASTM D5185m		949	1025	602

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>125	12	13	9
Sodium	ppm	ASTM D5185m		0	<1	3
Potassium	ppm	ASTM D5185m	>20	2	0	<1
Water	%	ASTM D6304	>0.1	0.083	0.081	▲ 0.146
ppm Water	ppm	ASTM D6304	>1000	833.2	818.3	▲ 1460






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	▲ 80484	---	---
Particles >6µm	ASTM D7647	>2500	▲ 5289	---	---
Particles >14µm	ASTM D7647	>320	166	---	---
Particles >21µm	ASTM D7647	>80	43	---	---
Particles >38µm	ASTM D7647	>20	2	---	---
Particles >71µm	ASTM D7647	>4	0	---	---
Oil Cleanliness	ISO 4406 (c)	>20/18/15	▲ 24/20/15	---	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	▲ 4.24	▲ 3.83	▲ 3.829


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	LIGHT
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	54.3	54.5	54.8
Visc @ 100°C	cSt	ASTM D445	9.5	9.6	10.7
Viscosity Index (VI)	Scale	ASTM D2270	159	161	190

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0828728 **Received** : 19 Jul 2023
Lab Number : 05902278 **Diagnosed** : 21 Jul 2023
Unique Number : 10563634 **Diagnostician** : Jonathan Hester
Test Package : MOB 2 (Additional Tests: KF, KV100, PrtCount, VI)

BASF - GIANNA CREDAROLI
 500 WHITE PLAINS RD
 TARRYTOWN, NY
 US 10591
 Contact: GIANNA CREDAROLI
 gianna.credaroli@basf.com

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)