

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

BEACH 4 BEACH (S/N 15766)

Pump Fluid USPI VAC 100 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.








SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM28460	USPM26730	USPM24610
Sample Date		Client Info		18 Jul 2023	20 Feb 2023	06 Nov 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	ATTENTION	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	3	<1	1
Chromium	ppm	ASTM D5185m	>5	0	0	0
Nickel	ppm	ASTM D5185m	>5	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>7	2	0	<1
Lead	ppm	ASTM D5185m	>12	0	0	<1
Copper	ppm	ASTM D5185m		0	0	<1
Tin	ppm		>9	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	<1
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	0	<1	0	2
Calcium	ppm	ASTM D5185m	0	0	<1	3
Phosphorus	ppm	ASTM D5185m	1800	962	1018	1266
Zinc	ppm	ASTM D5185m	0	6	7	10
Sulfur	ppm	ASTM D5185m	0	80	92	78
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	9	5	6
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Water	%	ASTM D6304		0.044	0.030	0.030
ppm Water	ppm	ASTM D6304	>.1	447.8	305.4	308.8
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	68	4363	343
Particles >6µm		ASTM D7647	>1300	17	1 380	92
Particles >14µm		ASTM D7647	>160	5	160	11
Particles >21µm		ASTM D7647	>40	2	46	4
Particles >38µm		ASTM D7647	>10	0	8	1
Particles >71µm		ASTM D7647	>3	0	1	0
Oil Cleanliness		ISO 4406 (c)	>19/17/14	13/11/10	▲ 19/18/14	16/14/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.05	0.09	0.08	0.06



OIL ANALYSIS REPORT








	14μ	m				A
0k						11
0k -						11
5k - Abno	irmal					++
0k	-				\frown	N
Feb6/17 -	Dec28/17.	0ct22/18.	Aug13/19 .	Jun15/20	Apr12/21.	Feb8/22 -
ep	ec2	ct2	B	lu	prl	Feb

Certificate L2367

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual		NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	91	80.8	83.2	83.4
SAMPLE IMAGE	S	method	limit/base	current	history1	history2
Color					Hounn 84 9:3041044 HRWYA	



Bottom



US 18853 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Test Package : IND 2

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: SERVICE MANAGER ? - CARWYA

T:

F: