




# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Area  
**CRM64**  
 Machine Id  
**CRM 64 FEED LEVELER REDUCER (S/N 16-2300-0130)**  
 Component  
**Gearbox**  
 Fluid  
**NOT GIVEN (--- QTS)**



## DIAGNOSIS

### Recommendation

Little or no information is provided as to the component and lubricant being tested. Recommendations are therefore generic in nature and may not apply to the current application. Please forward information as to equipment type, reservoir capacity, lubricant type and any pertinent information to allow for a more accurate assessment. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample. Please specify the brand, type, and viscosity of the oil on your next sample.

### Wear

All component wear rates are normal.

### Contamination

The water content is negligible. There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

|               | method      | limit/base  | current            | history1    | history2    |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info |             | <b>RP0035017</b>   | RP0031211   | RP0030896   |
| Sample Date   | Client Info |             | <b>17 Jul 2023</b> | 15 Mar 2023 | 13 Dec 2022 |
| Machine Age   | hrs         | Client Info | <b>0</b>           | 0           | 0           |
| Oil Age       | hrs         | Client Info | <b>0</b>           | 0           | 0           |
| Oil Changed   | Client Info |             | <b>N/A</b>         | N/A         | N/A         |
| Sample Status |             |             | <b>NORMAL</b>      | NORMAL      | NORMAL      |

## WEAR METALS

|          | method     | limit/base       | current      | history1 | history2 |
|----------|------------|------------------|--------------|----------|----------|
| PQ       | ASTM D8184 |                  | <b>24</b>    | 24       | 21       |
| Iron     | ppm        | ASTM D5185m >200 | <b>15</b>    | 11       | 15       |
| Chromium | ppm        | ASTM D5185m >15  | <b>0</b>     | <1       | 0        |
| Nickel   | ppm        | ASTM D5185m >15  | <b>0</b>     | 0        | 0        |
| Titanium | ppm        | ASTM D5185m      | <b>&lt;1</b> | <1       | <1       |
| Silver   | ppm        | ASTM D5185m      | <b>0</b>     | 0        | 0        |
| Aluminum | ppm        | ASTM D5185m >25  | <b>4</b>     | 10       | 3        |
| Lead     | ppm        | ASTM D5185m >100 | <b>0</b>     | 0        | 0        |
| Copper   | ppm        | ASTM D5185m >200 | <b>0</b>     | 0        | 0        |
| Tin      | ppm        | ASTM D5185m >25  | <b>0</b>     | 0        | 0        |
| Vanadium | ppm        | ASTM D5185m      | <b>0</b>     | <1       | 0        |
| Cadmium  | ppm        | ASTM D5185m      | <b>0</b>     | 0        | 0        |

## ADDITIVES

|            | method | limit/base  | current      | history1 | history2 |
|------------|--------|-------------|--------------|----------|----------|
| Boron      | ppm    | ASTM D5185m | <b>&lt;1</b> | 2        | 1        |
| Barium     | ppm    | ASTM D5185m | <b>0</b>     | 0        | 0        |
| Molybdenum | ppm    | ASTM D5185m | <b>0</b>     | 1        | 0        |
| Manganese  | ppm    | ASTM D5185m | <b>0</b>     | <1       | <1       |
| Magnesium  | ppm    | ASTM D5185m | <b>&lt;1</b> | 2        | 0        |
| Calcium    | ppm    | ASTM D5185m | <b>27</b>    | 26       | 30       |
| Phosphorus | ppm    | ASTM D5185m | <b>107</b>   | 93       | 104      |
| Zinc       | ppm    | ASTM D5185m | <b>5</b>     | 0        | 4        |





## CONTAMINANTS

|           | method | limit/base       | current      | history1 | history2 |
|-----------|--------|------------------|--------------|----------|----------|
| Silicon   | ppm    | ASTM D5185m >50  | <b>8</b>     | 6        | 7        |
| Sodium    | ppm    | ASTM D5185m      | <b>0</b>     | <1       | <1       |
| Potassium | ppm    | ASTM D5185m >20  | <b>&lt;1</b> | 0        | 0        |
| Water     | %      | ASTM D6304 >0.2  | <b>0.007</b> | 0.008    | 0.013    |
| ppm Water | ppm    | ASTM D6304 >2000 | <b>75.5</b>  | 85.1     | 136.2    |

## FLUID DEGRADATION

|                  | method   | limit/base | current     | history1 | history2 |
|------------------|----------|------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | <b>0.25</b> | 0.25     | 0.26     |

# OIL ANALYSIS REPORT








| VISUAL           | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal      | scalar | *Visual    | NONE    | NONE     | NONE     |
| Yellow Metal     | scalar | *Visual    | NONE    | NONE     | NONE     |
| Precipitate      | scalar | *Visual    | NONE    | NONE     | NONE     |
| Silt             | scalar | *Visual    | NONE    | NONE     | NONE     |
| Debris           | scalar | *Visual    | NONE    | NONE     | NONE     |
| Sand/Dirt        | scalar | *Visual    | NONE    | NONE     | NONE     |
| Appearance       | scalar | *Visual    | NORML   | NORML    | NORML    |
| Odor             | scalar | *Visual    | NORML   | NORML    | NORML    |
| Emulsified Water | scalar | *Visual    | >0.2    | NEG      | NEG      |
| Free Water       | scalar | *Visual    |         | NEG      | NEG      |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| Visc @ 40°C      | cSt    | ASTM D445  | 337     | 341      | 336      |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : RP0035017 **Received** : 19 Jul 2023  
**Lab Number** : 05902356 **Diagnosed** : 20 Jul 2023  
**Unique Number** : 10563712 **Diagnostician** : Wes Davis  
**Test Package** : IND 2 ( Additional Tests: PQ )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**OUTOKUMPU STAINLESS USA**  
 HWY 43 N  
 CALVERT, AL  
 US 36513  
 Contact: MARIO JOHNSON  
 Mario.johnson@outokumpu.com  
 T: (251)321-4105  
 F: x: