




PROBLEM SUMMARY

Sample Rating Trend




WATER




Machine Id
MATTEI A7DLTZ-2017
 Component
Compressor
 Fluid
ROTOROIL 8000 (4 GAL)

COMPONENT CONDITION SUMMARY

▲ Acid Number



▲ Water



RECOMMENDATION

The oil is near the end of its useful service life, recommend schedule an oil change. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	SEVERE
Water	%	ASTM D6304	>0.1	▲ 0.115	0.037	▲ 0.171
ppm Water	ppm	ASTM D6304	>1000	▲ 1152.6	373.8	▲ 1716.6
Acid Number (AN)	mg KOH/g	ASTM D8045	0.1	▲ 3.78	▲ 2.93	● 9.696

Customer Id: STAELKNC
 Sample No.: AN38957
 Lab Number: 05902378
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Service/change Fluid	---	---	?	The oil is near the end of it's useful service life, recommend schedule an oil change.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

01 Feb 2023 Diag: Jonathan Hester

DEGRADATION



The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is above the recommended limit.

view report



02 Sep 2022 Diag: Jonathan Hester

DEGRADATION



Recommend drain oil if not already done and flush with cleaner before refilling with oil. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is above the recommended limit. TAN level indicates possible presence of varnish. The oil is no longer serviceable.

view report



25 Oct 2021 Diag: Jonathan Hester

DEGRADATION



The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is above the recommended limit.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
MATTEI A7DLTZ-2017
 Component
Compressor
 Fluid
ROTOROIL 8000 (4 GAL)

DIAGNOSIS

Recommendation

The oil is near the end of its useful service life, recommend schedule an oil change. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a light concentration of water present in the oil.

Fluid Condition

The AN level is at the top-end of the recommended limit.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		AN38957	AN38564	AN38645
Sample Date	Client Info		06 Jul 2023	01 Feb 2023	02 Sep 2022
Machine Age	hrs	Client Info	17316	14861	12824
Oil Age	hrs	Client Info	2455	4607	2570
Oil Changed	Client Info		Not Changed	Changed	Not Changed
Sample Status			ABNORMAL	ABNORMAL	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	18	7	14
Chromium	ppm	ASTM D5185m >10	0	0	0
Nickel	ppm	ASTM D5185m	0	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	4	1	5
Lead	ppm	ASTM D5185m >25	<1	0	<1
Copper	ppm	ASTM D5185m >50	4	3	5
Tin	ppm	ASTM D5185m >15	<1	0	<1
Antimony	ppm	ASTM D5185m	---	---	---
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	<1	1
Magnesium	ppm	ASTM D5185m	2	6	7
Calcium	ppm	ASTM D5185m	11	13	6
Phosphorus	ppm	ASTM D5185m 884	895	844	678
Zinc	ppm	ASTM D5185m	44	22	128
Sulfur	ppm	ASTM D5185m	38	0	51

CONTAMINANTS




	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	1	2	2
Sodium	ppm	ASTM D5185m	18	16	18
Potassium	ppm	ASTM D5185m >20	2	<1	<1
Water	%	ASTM D6304 >0.1	▲ 0.115	0.037	▲ 0.171
ppm Water	ppm	ASTM D6304 >1000	▲ 1152.6	373.8	▲ 1716.6

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.1	▲ 3.78	▲ 2.93	■ 9.696




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	87.69	69.5	67.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : AN38957
 Lab Number : 05902378
 Unique Number : 10563734
 Test Package : IND 2

STANLEY HEATING & AIR
 1002 DOBBINS MILL RD
 ELKIN, NC
 US 28621
 Contact: DARRYL WEDDLE

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (336)366-4226

F: