



PROBLEM SUMMARY

Area
CANNING
Machine Id
SEAM TEAR DROP
Component
Gearbox
Fluid
LUBRIPLATE SFGO ULTRA 220 (3 GAL)

Sample Rating Trend



COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	SEVERE
Water	%	ASTM D6304	>0.2	▲ 0.525	▲ 0.305	● 3.36
ppm Water	ppm	ASTM D6304	>2000	▲ 5250	▲ 3050	● 33600
Appearance	scalar	*Visual	NORML	▲ LAYRD	▲ SOLID	NORML
Free Water	scalar	*Visual		● >10%	▲ >10%	NEG

Customer Id: PEPTUL
Sample No.: TO10002001
Lab Number: 05902619
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Check Water Access	---	---	?	We advise that you check for the source of water entry.

HISTORICAL DIAGNOSIS

01 Jun 2023 Diag: Jonathan Hester

WATER



No corrective action is recommended at this time. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a light concentration of water present in the oil. Sample is layered with different type/density oil. The condition of the oil is acceptable for the time in service.

[view report](#)



22 May 2023 Diag: Jonathan Hester

WATER



We advise that you check for the source of water entry. We recommend that you drain the oil from the component if this has not already been done. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a high concentration of water present in the oil. Viscosity of sample indicates oil is within ISO 460 range, advise investigate. Confirm oil type. The oil is no longer serviceable due to the presence of contaminants.

[view report](#)



06 Mar 2023 Diag: Doug Bogart

VIS DEBRIS




We suspect abnormal contamination may be due to sampling method. No corrective action is recommended at this time. Resample at the next service interval to monitor. Please note that this is a corrected copy for laboratory data update for water value. All component wear rates are normal. Water content negligible. Moderate concentration of visible dirt/debris present in the oil. The condition of the oil is acceptable for the time in service.

[view report](#)





Area
CANNING
 Machine Id
SEAM TEAR DROP
 Component
Gearbox
 Fluid
LUBRIPLATE SFGO ULTRA 220 (3 GAL)



DIAGNOSIS

Recommendation
 We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition.

Wear
 All component wear rates are normal.

Contamination
 Excessive free water present. There is a moderate concentration of water present in the oil.

Fluid Condition
 The oil is no longer serviceable due to the presence of contaminants.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		TO10002001	TO10001895	TO10001901
Sample Date	Client Info		17 Jul 2023	01 Jun 2023	22 May 2023
Machine Age	wks	Client Info	0	0	0
Oil Age	wks	Client Info	0	0	0
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			SEVERE	ABNORMAL	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184		25	27	46
Iron	ppm	ASTM D5185m >200	16	9	13
Chromium	ppm	ASTM D5185m >15	<1	0	<1
Nickel	ppm	ASTM D5185m >15	0	0	1
Titanium	ppm	ASTM D5185m	0	<1	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	<1	<1	0
Lead	ppm	ASTM D5185m >100	1	0	0
Copper	ppm	ASTM D5185m >200	1	1	2
Tin	ppm	ASTM D5185m >25	<1	0	<1
Vanadium	ppm	ASTM D5185m	0	0	<1
Cadmium	ppm	ASTM D5185m	0	0	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	20
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	<1
Manganese	ppm	ASTM D5185m	<1	0	<1
Magnesium	ppm	ASTM D5185m	0	<1	3
Calcium	ppm	ASTM D5185m	4	19	20
Phosphorus	ppm	ASTM D5185m	183	270	651
Zinc	ppm	ASTM D5185m	0	0	15
Sulfur	ppm	ASTM D5185m	2660	1940	1129






CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	7	8	31
Sodium	ppm	ASTM D5185m	<1	<1	6
Potassium	ppm	ASTM D5185m >20	8	0	<1
Water	%	ASTM D6304 >0.2	▲ 0.525	▲ 0.305	● 3.36
ppm Water	ppm	ASTM D6304 >2000	▲ 5250	▲ 3050	● 33600

VISUAL


	method	limit/base	current	history1	history2
White Metal	scalar	*Visual NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual NONE	NONE	NONE	NONE
Silt	scalar	*Visual NONE	MODER	MODER	NONE
Debris	scalar	*Visual NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual NONE	NONE	NONE	NONE
Appearance	scalar	*Visual NORML	▲ LAYRD	▲ SOLID	NORML
Odor	scalar	*Visual NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual >0.2	0.2%	0.2%	● 0.2%
Free Water	scalar	*Visual	● >10%	▲ >10%	NEG

OIL ANALYSIS REPORT








FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	222	208	217
Visc @ 100°C	cSt	ASTM D445	26	20.1	26.0
Viscosity Index (VI)	Scale	ASTM D2270	146	111	152

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : TO10002001 **Received** : 19 Jul 2023
Lab Number : 05902619 **Diagnosed** : 21 Jul 2023
Unique Number : 10563975 **Diagnostician** : Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, KV100, PQ, VI)

PEPSI BOTTLING GROUP
 510 W SKELLY DR
 TULSA, OK
 US 74107
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)