




# PROBLEM SUMMARY




Sample Rating Trend

VISUAL METAL



Machine Id  
**COOLANT**  
Component  
**Cutting Fluid**  
Fluid  
**PPC CUT (6000 GAL)**

## COMPONENT CONDITION SUMMARY



## RECOMMENDATION

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. Please submit a sample of the new (unused) oil to establish a baseline.

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	---
Aluminum	ppm	ASTM D6130		▲ 123	▲ 69	---
Lead	ppm	ASTM D6130		▲ 379	▲ 443	---
Copper	ppm	ASTM D6130		▲ 172	▲ 206	---
Silicon	ppm	ASTM D6130		▲ 143	▲ 95	---
White Metal	scalar	*Visual	NONE	● HEAVY	● MODER	---

Customer Id: PPCEAS  
Sample No.: WC0788793  
Lab Number: 05902694  
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	We recommend an early resample to monitor this condition. Please submit a sample of the new (unused) oil to establish a baseline.
Filter Fluid	---	---	?	We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid.

## HISTORICAL DIAGNOSIS

31 Jan 2023 Diag: Doug Bogart

### VISUAL METAL



We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. Please submit a sample of the new (unused) oil to establish a baseline. The metal levels are abnormal. Moderate concentration of visible metal present. Elemental level of silicon (Si) above normal indicating ingress of seal material. The AN level is acceptable for this fluid.

view report






# OIL ANALYSIS REPORT

Sample Rating Trend

VISUAL METAL



Machine Id  
**COOLANT**  
 Component  
**Cutting Fluid**  
 Fluid  
**PPC CUT (6000 GAL)**

## DIAGNOSIS

### Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. Please submit a sample of the new (unused) oil to establish a baseline.

### Wear

The metal levels are abnormal. Heavy concentration of visible metal present.

### Contamination

Elemental level of silicon (Si) above normal indicating ingress of seal material.

### Fluid Condition

The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0788793</b>	WC0661351	---
Sample Date	Client Info		<b>13 Jul 2023</b>	31 Jan 2023	---
Machine Age	mths	Client Info	<b>0</b>	0	---
Oil Age	mths	Client Info	<b>11</b>	11	---
Oil Changed	Client Info		<b>N/A</b>	Not Changd	---
Sample Status			<b>SEVERE</b>	SEVERE	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130	<b>12</b>	8	---
Chromium	ppm	ASTM D6130	<b>0</b>	0	---
Nickel	ppm	ASTM D6130	<b>0</b>	0	---
Titanium	ppm	ASTM D6130	<b>&lt;1</b>	<1	---
Silver	ppm	ASTM D6130	<b>0</b>	0	---
Aluminum	ppm	ASTM D6130	<b>▲ 123</b>	▲ 69	---
Lead	ppm	ASTM D6130	<b>▲ 379</b>	▲ 443	---
Copper	ppm	ASTM D6130	<b>▲ 172</b>	▲ 206	---
Tin	ppm	ASTM D6130	<b>0</b>	<1	---
Vanadium	ppm	ASTM D6130	<b>&lt;1</b>	0	---
Cadmium	ppm	ASTM D6130	<b>0</b>	0	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D6130	<b>0</b>	0	---
Barium	ppm	ASTM D6130	<b>0</b>	0	---
Molybdenum	ppm	ASTM D6130	<b>2</b>	1	---
Manganese	ppm	ASTM D6130	<b>&lt;1</b>	<1	---
Magnesium	ppm	ASTM D6130	<b>27</b>	11	---
Calcium	ppm	ASTM D6130	<b>91</b>	68	---
Phosphorus	ppm	ASTM D6130	<b>325</b>	314	---
Zinc	ppm	ASTM D6130	<b>280</b>	228	---
Sulfur	ppm	ASTM D6130	<b>1645</b>	1904	---

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130	<b>▲ 143</b>	▲ 95	---
Sodium	ppm	ASTM D6130	<b>38</b>	34	---
Potassium	ppm	ASTM D6130 >20	<b>10</b>	9	---

## FLUID DEGRADATION






	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	<b>0.173</b>	0.17	---

## VISUAL

	method	limit/base	current	history1	history2
White Metal	scalar	*Visual NONE	<b>HEAVY</b>	MODER	---
Yellow Metal	scalar	*Visual NONE	<b>NONE</b>	NONE	---
Precipitate	scalar	*Visual NONE	<b>NONE</b>	NONE	---
Silt	scalar	*Visual NONE	<b>NONE</b>	NONE	---
Debris	scalar	*Visual NONE	<b>NONE</b>	NONE	---
Sand/Dirt	scalar	*Visual NONE	<b>NONE</b>	NONE	---
Appearance	scalar	*Visual NORML	<b>NORML</b>	▲ HAZY	---
Odor	scalar	*Visual NORML	<b>NORML</b>	NORML	---
Emulsified Water	scalar	*Visual	<b>NEG</b>	NEG	---
Free Water	scalar	*Visual	<b>NEG</b>	NEG	---







# OIL ANALYSIS REPORT



FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445		43.76	43.54	---

SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						no image
Bottom						no image

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0788793 **Received** : 19 Jul 2023  
**Lab Number** : 05902694 **Diagnosed** : 25 Jul 2023  
**Unique Number** : 10564050 **Diagnostician** : Doug Bogart  
**Test Package** : IND 2

**PPC BROADBAND, INC**  
 6176 E MOLLOY RD  
 EAST SYRACUSE, NY  
 US 13057  
 Contact: JIM DEVINE  
 jdevine@ppc-online.com  
 T: (315)431-7337  
 F:

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)