

## **FUEL REPORT**

## **WATER**



# UNC ROCKINGHAM - 20K VST

Component **Diesel Fuel** 

DIESEL FUEL No. 2 (20000 GAL)

## **DIAGNOSIS**

#### Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We advise that you inspect for the source(s) of rust. All other laboratory tests indicate that this sample meets specifications for No.2 low-sulfur diesel fuel.

### Corrosion


Moderate concentration of visible metal present as rust.

#### Contaminants

Free water present. Moderate concentration of visible dirt/debris present in the fuel. There is no bacteria or fungus (yeast and/or mold) present in the sample.

#### **Fuel Condition**


The fuel is still serviceable provided that the contaminant(s) can be reduced to acceptable levels. Sulfur value derived by ASTM D5453 method for ULSD validation.



SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0787040		
Sample Date		Client Info		14 Jul 2023		
Machine Age	hrs	Client Info		0		
Sample Status				ABNORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.849		
Fuel Color	text	*Visual Screen		Red		
ASTM Color	scalar	*ASTM D1500		L5.5		
Visc @ 40°C	cSt	ASTM D445	4.1	2.49		
Pensky-Martens Flash Point	°C	*PMCC Calculated		57		
SULFUR CONTE	VT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		1104		
Sulfur (UVF)	ppm	ASTM D5453		900		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		160		
5% Distillation Point	°C	ASTM D86		194		
10% Distill Point	°C	ASTM D86		205		
15% Distillation Point	°C	ASTM D86		214		
20% Distill Point	°C	ASTM D86		222		
30% Distill Point	°C	ASTM D86		237		
40% Distill Point	°C	ASTM D86		248		
50% Distill Point	°C	ASTM D86		261		
60% Distill Point	°C	ASTM D86		273		
70% Distill Point	°C	ASTM D86		286		
80% Distill Point	°C	ASTM D86		302		
85% Distillation Point	°C	ASTM D86		311		
90% Distill Point	°C	ASTM D86		323		
95% Distillation Point	°C	ASTM D86		341		
Final Boiling Point	°C	ASTM D86		350		
Distillation Residue	%	ASTM D86		1.4		
Distillation Loss	%	ASTM D86		0.5		
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777		35.2		
Cetane Index		ASTM D4737	<40.0	42.8		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	<1		
Potassium	ppm	ASTM D5185m	<0.1	<1		
Water	%	ASTM D6304	< 0.05	0.007		
ppm Water	ppm	ASTM D6304	<500	78.7		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		



## **FUEL REPORT**





Certificate L2367

Laboratory Sample No. Lab Number Unique Number

: 05902706 : 10564062

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0787040 Received : 19 Jul 2023 Diagnosed : 18 Aug 2023

Diagnostician : Doug Bogart Test Package : DF-2 (Additional Tests: Bacteria, Screen)

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

**VITAL FUEL SYSTEMS** 1076 CLASSIC RD

APEX, NC US 27539

Contact: JOHN MORREALE jmorreale@vitalfuelsystems.com

T: (919)629-8180 F: (919)303-7399

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)